Begum Fatema (Place _Sustainability)

From: BCTAdmin@thameswater.co.uk
Sent: 18 March 2015 14:56
To: DM & BC Support Team
Subject: 3rd Party Planning Application - HGY/2015/0731

London Borough of Haringey
639 High Road
HGY/2015/0731
Tottenham
London
N17 8BD

Our DTS Ref: 45378
Your Ref:

18 March 2015

Dear Sir/Madam

Re: LAND AT, TAYLOR CLOSE, LONDON, N17 0UB

Waste Comments
Legal changes under The Water Industry (Scheme for the Adoption of private sewers) Regulations 2011 mean that the sections of pipes you share with your neighbours, or are situated outside of your property boundary which connect to a public sewer are likely to have transferred to Thames Water's ownership. Should your proposed building work fall within 3 metres of these pipes we recommend you contact Thames Water to discuss their status in more detail and to determine if a building over / near to agreement is required. You can contact Thames Water on 0800 009 3921 or for more information please visit our website at www.thameswater.co.uk

Surface Water Drainage - With regard to surface water drainage it is the responsibility of a developer to make proper provision for drainage to ground, water courses or a suitable sewer. In respect of surface water it is recommended that the applicant should ensure that storm flows are attenuated or regulated into the receiving public network through on or off site storage. When it is proposed to connect to a combined public sewer, the site drainage should be separate and combined at the final manhole nearest the boundary. Connections are not permitted for the removal of groundwater. Where the developer proposes to discharge to a public sewer, prior approval from Thames Water Developer Services will be required. They can be contacted on 0800 009 3921. Reason - to ensure that the surface water discharge from the site shall not be detrimental to the existing sewerage system.

Thames Water would advise that with regard to sewerage infrastructure capacity, we would not have any objection to the above planning application.

Water Comments
On the basis of information provided, Thames Water would advise that with regard to water infrastructure capacity, we would not have any objection to the above planning application.

Thames Water recommend the following informative be attached to this planning permission. Thames Water will aim to provide customers with a minimum pressure of 10m head (approx 1 bar) and a flow rate of 9 litres/minute at the point where it leaves Thames Waters pipes. The developer should take account of this minimum pressure in the design of the proposed development.

Yours faithfully
Development Planning Department

Development Planning,
Thames Water,
Maple Lodge STW,
Denham Way,
Rickmansworth,
WD3 9SQ