## Zanelli Marco

**Subject:** FW: Internal Consultation - App ref HGY/2015/0453

**From:** Ni Hogain Sadhbh
**Sent:** 24 March 2015 16:45
**To:** Flynn Adam
**Cc:** Zanelli Marco; Sullivan Simone
**Subject:** RE: Internal Consultation - App ref HGY/2015/0453

Adam

Please see comments below on the sustainability statement – I do not think there are any further conditions or queries.

a. If the developer if proposing installing MHVR units – will air pressure testing be carried out to verify 5.3/hm2 is being achieved?
b. Once the Design Stage Assessment is completed the developer should submit the CfSH interim certificate
c. In addition, once completed the developer needs to submit the CfSH final certification and the BREEAM certificate

Let me know if there is anything further.

Regards

Sadhbh Ní Hógáin
Housing Retrofit Project Manager
(Retrofit London ERDF Project Manager)
T: 020 8489 4509
sadhbh.nihogain@haringey.gov.uk

HARINGEY 4020
An initiative of Haringey Council

*Please help to save paper by not printing this email unless absolutely necessary*