Begum Fatema (Place _Sustainability)

From: BCTAdmin@thameswater.co.uk
Sent: 21 April 2015 09:59
To: Planning Support
Subject: 3rd Party Planning Application - HGY/2015/1050

London Borough of Haringey
639 High Road
HGY/2015/1050
Tottenham
London
N17 8BD

Our DTS Ref: 45804
Your Ref:

21 April 2015

Dear Sir/Madam

Re: 236, ARCHWAY ROAD, LONDON, GREATER LONDON, N6 5AX

Waste Comments
Thames Water would advise that with regard to sewerage infrastructure capacity, we would not have any objection to the above planning application.

There are public sewers crossing or close to your development. In order to protect public sewers and to ensure that Thames Water can gain access to those sewers for future repair and maintenance, approval should be sought from Thames Water where the erection of a building or an extension to a building or underpinning work would be over the line of, or would come within 3 metres of, a public sewer. Thames Water will usually refuse such approval in respect of the construction of new buildings, but approval may be granted in some cases for extensions to existing buildings. The applicant is advised to contact Thames Water Developer Services on 0800 009 3921 to discuss the options available at this site.

Surface Water Drainage - With regard to surface water drainage it is the responsibility of a developer to make proper provision for drainage to ground, water courses or a suitable sewer. In respect of surface water it is recommended that the applicant should ensure that storm flows are attenuated or regulated into the receiving public network through on or off site storage. When it is proposed to connect to a combined public sewer, the site drainage should be separate and combined at the final manhole nearest the boundary. Connections are not permitted for the removal of groundwater. Where the developer proposes to discharge to a public sewer, prior approval from Thames Water Developer Services will be required. They can be contacted on 0800 009 3921. Reason - to ensure that the surface water discharge from the site shall not be detrimental to the existing sewerage system.

Water Comments
On the basis of information provided, Thames Water would advise that with regard to water infrastructure capacity, we would not have any objection to the above planning application.

Yours faithfully
Development Planning Department

Development Planning,
Thames Water,

Maple Lodge STW,
Denham Way,
Rickmansworth,
WD3 9SQ
Tel:020 3577 9998
Email: devcon.team@thameswater.co.uk

This is an automated email, please do not reply to the sender. If you wish to reply to this email, send to devcon.team@thameswater.co.uk

Did you know you can manage your account online? Pay a bill, set up a Direct Debit, change your details or even register a change of address at the click of a button, 24 hours a day. Please visit www.thameswater.co.uk.

Thames Water Limited (company number 2366623) and Thames Water Utilities Limited (company number 2366661) are companies registered in England and Wales each with their registered office at Clearwater Court, Vastern Road, Reading, Berkshire RG1 8DB. This email is confidential and intended solely for the use of the individual to whom it is addressed. Any views or opinions presented are solely those of the author and do not necessarily represent those of Thames Water Limited or its subsidiaries. If you are not the intended recipient of this email you may not copy, use, forward or disclose its contents to any other person; please notify our Computer Service Desk on +44 (0) 203 577 8888 and destroy and delete the message and any attachments from your system.

We provide the essential service that's at the heart of daily life.

This email has been scanned by the Symantec Email Security.cloud service.
For more information please visit http://www.symanteccloud.com