Skapoullis Jon

From: Planning Support
Subject: FW: Edgecot Grove N15 5HH HGY/2015/3479 Proposed Youth Centre

From: Williams Millie
Sent: 11 February 2016 11:49
To: Planning Customer Care Team
Cc: Chenier Pierre
Subject: Edgecot Grove N15 5HH HGY/2015/3479 Proposed Youth Centre

Dear Planning Team,

I have not been able to make comments for the Application **HGY/2015/3479** because the Portal was not allowing access until after the Final Date For Consultation on the 23rd December 2015.

1. The number of WC's for a Youth Centre is detailed in the Drawing Plans as One (1). The basic minimum provision of WC's for Employees to meet the Statutory Requirement i.e. Workplace (Health Safety and Welfare) Regulations 1992 is 1 x WC and 1 x Wash Hand Basin for 1 to 5 Females or Mixed Use and 1 x WC and 1x Urinal and 1 x Wash Hand Basin for 1 to 15 Males.

2. There should also be 1 x WC for Disabled Use with a Wash Hand Basin.

3. All Provision of WC's must be adequately ventilated and lit.

4. The basic minimum provision for the Young Persons and Public who the Centre is being built for is decided by Building Control.

Please can these comments be considered for the Planning Application.

Regards,

Millie Williams
Environmental Health Practitioner

Haringey Council
Level 6 Alexandra House, 10 Station Road, London N22 7TR

T. 020 8489 5522
E. millie.williams@haringey.gov.uk

www.haringey.gov.uk
twitter@haringeycouncil
facebook.com/haringeycouncil

Please consider the environment before printing this email.