Environmental Services and Community Safety

Tracie Evans – Chief Operating Officer

Anthony Traub
Planning

Date: 16 March 2016
Your ref:
Our ref:

Dear Anthony

Re: Mowlem Trading Estate, Leeside Road, London, N17 0QJ
Planning application: - HGY/2016/0640

The above application is for the Approval of details pursuant to condition 5 (details of the gas fuelled generators) attached to planning permission HGY/2015/132.

The applicant has submitted a manufacturer's data sheet to discharge Condition 5:

No development hereby approved shall commence until details of the gas fuelled generators have been submitted to, and approved in writing by the Local Planning Authority. Details shall include, but not limited to, evidence that demonstrate that the units to be installed comply with the Medium Combustion Plant Directive -NO2 Limit.
Reason: To maintain air quality in accordance with saved UDP 2006 policy ENV7 and London Plan 2015 policy 7.14.

Appendix A (Cummins data sheet) provides the NOX emission for the engines as 250 mg/Nm3 at 5% O2 however the covering letter refers to the emissions from the engine 'as 50mg/Nm3 at 5% oxygen'. The emission limit value according to Annex 2, Part 1, Table 3 is 190mg/Nm3 at 15% oxygen. The emission value from the engines of 250 mg/Nm3 at 5% O_2 converts approximately to 110 mg/Nm3 at 15%; this would still comply with limit value for 'existing' engines.
Therefore this condition can be discharged.

Yours sincerely

Kyri Eleftheriou-Vaus
Lead Officer – Pollution.

Regulatory Services
Alexandra House
6th Floor, 10 Station Road
Wood Green

T: 0208 489 1000
E: Kyri.Eleftheriou-Vaus@Haringey.gov.uk

www.haringey.gov.uk