LONDON FIRE
AND EMERGENCY
PLANNING AUTHORITY

Fire Safety Regulation
169 Union Street London SE1 0LL
T 020 8555 1200 x89171

Minicom 020 7960 3629
london-fire.gov.uk

Aaron Lau
London Borough of Haringey
Planning & Regeneration
6th Floor
River Park House
225 High Road
Wood Green
London
N22 8HQ

Haringey Council
Place & Sustainability
Planning, Regeneration & Economy
10 JUN 2016
Received
6th Floor River Park House
225 High Road N22 8HQ

London Fire and Emergency Planning
Authority runs the London Fire Brigade

Date 02/06/ 2016
Our Ref 31/164103
Your Ref HGY/2016/0801

Dear Sir/Madam

RECORD OF CONSULTATION/ADVICE GIVEN

REGULATORY REFORM (FIRE SAFETY) ORDER 2005 ARTICLE 45.
THE BUILDING (APPROVED INSPECTORS ETC.) REGULATIONS 2010.

SCOPE OF WORKS: Demolition of existing two storey dwelling house and erection of two storey dwelling-house with basement. Erection of plant enclosure within the garden, associated landscaping and boundary treatment.

PREMISES: 55 Sheldon Avenue, N6 4NH.

PLAN NUMBER(S) (if any):As per planning portal.

The Brigade has been consulted with regard to the above-mentioned premises and makes the following observations:

The brigade would be satisfied with the proposal subject to the following conditions.

Other comments: As per Approved Document B B5 for access and facilities for the fire service.

This Authority strongly recommends that sprinklers are considered for new developments and major alterations to existing premises, particularly where the proposals relate to schools and care homes. Sprinkler systems installed in buildings can significantly reduce the damage caused by fire and the consequential cost to businesses and housing providers, and can reduce the risk to life. The Brigade opinion is that there are opportunities for developers and building owners to install sprinkler systems in order to save money, save property and protect the lives of occupier. Please note that it is our policy to regularly advise our elected Members about how many cases there have been where we have recommended sprinklers and what the outcomes of those recommendations were. These quarterly reports to our Members are public documents which are available on our website.

Any queries regarding this letter should be addressed to David Gregory. If you are dissatisfied in any way with the response given, please ask to speak to the Team Leader quoting our reference.

Yours faithfully,



Assistant Commissioner (Fire Safety Regulation)

Reply to David Gregory
Direct **T** 0208 555 1200 ext 38260

The London Fire Brigade promotes the installation of sprinkler suppression systems, as there is clear evidence that they are effective in suppressing and extinguishing fires; they can help reduce the numbers of deaths and injuries from fire, and the risk to firefighters.