LIST OF RECOMMENDATIONS UNDER DELEGATED POWERS

REPORT FOR CONSIDERATION UNDER DELEGATED POWERS

1. APPLICATION DETAILS

Reference No: HGY/2016/1073 **Ward:** Hornsey

Date received: 06/04/2016

Drawing number of plans: 1, 2, 3, 4, 5, 6, 7, 8

Address: 14 Boyton Close N8 7AY

Proposal: Certificate of lawfulness for rear dormer loft conversion

Applicant: Mr Paul Keogh

Ownership: Private

Case Officer: Duncan McKane

2. RECOMMENDATION

GRANT CERTIFICATE

3. RELEVANT PLANNING AND ENFORCEMENT HISTORY

- HGY/1995/0630 – Erection of ground floor extension – PNR, 01/08/1995

4. DETAILS OF PROPOSAL

This is an application for a certificate of lawfulness for the formation of a rear dormer loft conversion.

5. RELEVANT PLANNING LEGISLATION

The application has been made under section 192 of the Town and Country Planning Act 1990 and relevant amendments. This not a planning application but instead the applicant seeks confirmation that the proposed development is lawful. As such, the impact of the proposed development of the neighbour's amenities or the character of the area cannot be taken into consideration for this submission.

6. ANALYSIS/ASSESSMENT OF THE APPLICATION

Class B: The enlargement of a dwellinghouse consisting of an addition or alteration to its roof.

A certificate Lawfulness for a erection of rear dormer and hip to gable extension can be issued if the proposal meets all the criteria under The Town and Country Planning

(Generally Permitted Development) (England) Order 2015 – Part 1, Class B 'The enlargement of a dwellinghouse consisting of an addition or alteration to its roof'.

The current proposal will be assessed against these requirements as follows:

Class B.1. Requirement	Comment	Complies
a) permission to use the dwellinghouse as a dwellinghouse has not been granted only by virtue of Class M, N, P or Q of Part 3 of this Schedule (changes of use);		Yes
b) The height of the part of the dwellinghouse enlarged, improved or altered would not exceed the height of the highest part of the roof of the existing dwellinghouse.		Yes
c) The enlarged part of the dwellinghouse would not extend beyond the plane of any existing roof slope which forms the principal elevation of the dwellinghouse and fronts a highway.		Yes
d) The cubic content of the resulting roof space would not exceed the cubic content of the original roof space by more than i) 40 cubic metres in the case of a terrace house ii) 50 cubic metres in any other case;	Rear dormer: Height = 2.52m Depth = 3.62m Width = 5.34m Total cubic content = 24.36m3	Yes
e) it would not consist of or include— (i)the construction or provision of a veranda, balcony or raised platform, or (ii)the installation, alteration or replacement of a chimney, flue or soil and vent pipe	Installation of Juliet balcony to rear dormer extension - complies.	Yes
f) The dwellinghouse is not on article 1(5) land.		Yes

Development is permitted by Class B subject to the following conditions:

B.2. Conditions	Comment
(a) The materials used in any exterior work must be of a similar appearance to those used in the construction of the exterior of the existing dwellinghouse.	Materials to match existing
(b) The enlargement must be constructed so that— (ii) other than in the case of a hip-to-gable enlargement or an enlargement which joins the original roof to the roof of a rear or side extension— (aa) the eaves of the original roof are maintained or reinstated; and (bb) the edge of the enlargement closest to the eaves of the original roof is, so far as practicable, not less than 0.2 metres from the eaves, measured along the roof slope from the outside edge of the	Complies

eaves; and (ii) other than in the case of an enlargement which joins the original roof to the roof of a rear or side extension, no part of the enlargement extends beyond the outside face of any external wall of the original dwellinghouse	
Any upper-floor window located in a wall or roof slope forming a side elevation of the dwellinghouse shall be— (i) obscure-glazed, and (ii) non-opening unless the parts of the window which can be opened are more than 1.7 metres above the floor of the room in which the window is installed.	N/A

Class G: The installation, alteration or replacement of a chimney, flue or soil and vent pipe on a dwellinghouse

A certificate Lawfulness for a can be issued if the proposal meets all the criteria under The Town and Country Planning (Generally Permitted Development) (England) Order 2015 – Part 1, Class G 'The installation, alteration or replacement of a chimney, flue or soil and vent pipe on a dwellinghouse'.

The current proposal will be assessed against these requirements as follows:

Class G.1. Requirement	Comment	Complies
(a) permission to use the dwellinghouse as a dwellinghouse has been granted only by virtue of Class M, N, P or Q of Part 3 of this Schedule (changes of use);		Yes
b) the height of the chimney, flue or soil and vent pipe would exceed the highest part of the roof by 1 metre or more; or	Existing chimney stack to be removed	Yes
(c) in the case of a dwellinghouse on article 2(3) land, the chimney, flue or soil and vent pipe would be installed on a wall or roof slope which— (i) fronts a highway, and (ii) forms either the principal elevation or a side elevation of the dwellinghouse.		Yes

7.0 CIL APPLICABLE

The increase in internal floor area would not exceed 100sqm and therefore the proposal is not liable for the Major's CIL charge.

8.0 SUMMARY AND CONCLUSION

The proposed development constitutes permitted development by virtue of Schedule 2, Part 1, Classes B & G of the Town and Country Planning (General Permitted Development) Order 2015 and is considered to be lawful.

9.0 RECOMMENDATION

Grant Certificate

Registered No. HGY/2016/1073

Applicant's drawing No.(s) 1, 2, 3, 4, 5, 6, 7, 8

In pursuance of their powers under the above Acts and Order the London Borough of Haringey as local planning Authority hereby CERTIFY that the above proposal described by the applicant constitutes PERMITTED DEVELOPMENT and is therefore LAWFUL.

INFORMATIVE: Land Ownership
The applicant is advised that this planning permission does not convey the right to enter onto or build on land not within his ownership.

INFORMATIVE: Party Wall Act
The applicant's attention is drawn to the Party Wall Act 1996 which sets out requirements for notice to be given to relevant adjoining owners of intended works on a shared wall, on a boundary or if excavations are to be carried out near a neighbouring building.

INFORMATIVE: Hours of Construction Work
The applicant is advised that under the Control of Pollution Act 1974, construction work which will be audible at the site boundary will be restricted to the following hours:-

8.00am - 6.00pm Monday to Friday
8.00am - 1.00pm Saturday
and not at all on Sundays and Bank Holidays.