

FOR TOP FING REFER TO STRUCTURAL FIXING SOLUTIONS OR FIX DIRECT TO SECONDARY STEEL

LOAD BEARING INSULATION BLOCK (TICK OPTION BOX) WITH CLASS "0" ALUMINIUM FOIL FACING LOAD BEARING INSULATION TO OVERLAP SUPPORT BY A MINIMUM OF 20mm. EACH SIDE. FOIL TO BE DOUBLE TAPPED ON/TO ADJACENT INSULATION TO MAINTAIN VAPOUR SEAL

LOAD BEARING INSULATION:-

HIGH DENSITY INSULATION	
PHENOLIC FOAM	☒
HARDWOOD	
OTHER	

PIPE SUPPORT DETAIL

FROM RISER

TO HOT WATER OUTLETS WITHIN ROOM

DETAIL A - SECONDARY RETURN DETAIL SINGLE RISER

FROM RISER

TO HOT WATER OUTLETS WITHIN ROOMS

ROOM 1 ROOM 2

DETAIL A - SECONDARY RETURN DETAIL SHARED RISER

FROM RISER

TO HOT WATER OUTLETS WITHIN ROOMS

DETAIL B - DOUBLE RISER

