BROADWAY ANNEX

ROOF

RISER TO BE VENTILATED TO EXTERNAL

AAV, IV, FB FLUSHING BYPASS (SEE DETAIL E), DETAIL D

20mm 20mm 25mm 25mm 20mm

BP, FMD, DOC

WITHIN COMMON AREA WITHIN UNIT — BA_A204 BA_A203 BA_A202

WITHIN COMMON AREA WITHIN UNIT — BA_A205 BA_A206 BA_A201

SECOND FLOOR

25mm

20mm 25mm 25mm 25mm 25mm 20mm

BA_A105 BA_A106 BA_A101 — BA_A102 BA_A103 BA_A104

WITHIN COMMON AREA WITHIN UNIT — BA_103 BA_102 BA_104 BA_101

AAV, IV, FB FLUSHING BYPASS (SEE DETAIL E), BP, FMD, DOC

REFER TO DETAIL A — REFER TO DETAIL A

FIRST FLOOR

25mm 25 mm 25mm 25mm

GROUND

25mm 25mm 32mm

FLOW AND RETURN FROM ENERGY CENTRE. REFER TO DRAWING NO. 10687-M-04-M-0001(1) FOR CONTINUATION

MEWS

RISER TO BE VENTILATED TO EXTERNAL

ROOF

AAV, IV, FB FLUSHING BYPASS (SEE DETAIL E), BP, FMD, DOC

25mm 20mm 25mm 25mm 25mm 25mm

WITHIN COMMON AREA WITHIN UNIT — P M 203 P M 202 P M 201

SECOND FLOOR

25mm 20mm 20mm 20mm 20mm 20mm

WITHIN COMMON AREA WITHIN UNIT — P M 103 P M 102 P M 101

FIRST FLOOR

20mm

WITHIN COMMON AREA WITHIN UNIT — P M 001

REFER TO DETAIL A — P M 002 P M 003

GROUND

25mm 25mm 20mm 20mm 20mm

INSULATION DETAILS

'SECONDARY STEEL eg. ANGLE OR OPEN CHANNEL'

LOAD BEARING INSULATION BLOCK (TICK OPTION BOX) WITH CLASS "O" ALUMINIUM FOIL FACING. LOAD BEARING INSULANT TO OVERLAP SUPPORT BY A MINIMUM OF 25mm EACH SIDE. FOIL TO BE DOUBLE TAPED ONTO ADJACENT INSULATION TO MAINTAIN VAPOUR SEAL.

SECONDARY STEEL eg. CHANNEL OR BOX SECTION

STANDARD — EXTENDED

PIPE SUPPORT DETAIL



DETAIL M539/PHS/026 ROLLER BRACKET



DETAIL M539/PHS/035 - ANCHOR



INSULATION DETAILS





PIPE SUPPORT DETAIL



BS6129 STATES THAT THERE SHOULD BE A MAXIMUM SPACING OF 4 PIPE DIAMETERS FROM THE BELLOWS TO THE FIRST GUIDE AND 14 PIPE DIAMETERS FROM THIS TO THE SECOND GUIDE.



GUIDE TO BE USED: SEE DETAIL M539/PHS/026.
DETAIL E



PBV TO BE SET TO OPEN WHEN NO HU'S ARE CALLING FOR DEMAND TO PREVENT PUMPS PUSHING AGAINST A CLOSED HEAD. TO BE FITTED ON THE INDEX RUN.



Copyright, Designs and Patents Act 1988
The copyright & design right of the design documents & of the design remains that of Whitecode Ltd. All copies are only for the purpose of the application, they may not be used for any other purpose or copied without the express written permission of Whitecode Ltd.

Conflicts of Information
It still remains the responsibility of the Installer/contractor to ensure that there are no conflicts with information provided by ourselves & that of any manufacturers information or relevant requirements of statuary Bodies or Client specification/Err's. If any conflicts do exist it is the responsibility of the Installer/Contractor to inform The Consultant/Client immediately Verbally & in writing.

NOTICE TO HOUSE PURCHASERS - Property Misdescriptions Act 1991
The information contained from this e-working drawing and is not intended to be treated as descriptive material describing, in relation to any descriptive material describing, in relation to any descriptive particular property or development, any of the Specific Matters prescribed by an Order made under the above Act. The contents of this drawing may be subject to change at any time & alterations and variations can occur during the progress of the works without revision of the drawing. Consequently, the finished details, contents & dimensions of the finished construction may differ materially from those shown. Nor do the contents of this drawing constitute a contract, part of any contract or a warranty.

LEGEND

- AAV — AUTOMATIC AIR VALVE
- CS — COMMISSIONING SET
- DP — DIRT POCKET
- IV — NORMALLY OPEN ISOLATION VALVE
- IV — NORMALLY CLOSED ISOLATION VALVE
- TBV — THERMOSTATIC BYPASS VALVE
- PBV — PRESSURE BYPASS VALVE
- TP — TEMPERATURE PROBE POCKET FOR THERMOSTATIC VALVE
- BP — BINDER POINT
- FB — FLUSHING BYPASS (SEE DETAIL C)
- F — FLOW METER
- HM — HEAT METER
- T — TEMPERATURE SENSOR
- T — TEMPERATURE GAUGE
- NRV — NON RETURN VALVE
- DOC — DRAIN OFF COCK
- FB — FLUSHING BYPASS
- DPS — DIFFERENTIAL PRESSURE SENSOR (TREND)
- FP — FLUSHING POINT
- BV — BALANCING VALVE, WITH SELF-SEALING MEASURING POINTS AND POSITIVE SHUT-OFF, FROM IMI HYDRONICS STADIS/TAP RANGE.
- FMD — FLOW MEASURING DEVICE, AS PER BV/IV BUT SOLELY FOR THE PURPOSE OF FLOW MEASUREMENT AND ISOLATION ONLY. VALVE TO BE LEFT FULLY OPEN.
- IN-GROUND/BELOW-GROUND PIPEWORK

PLEASE NOTE THAT ALL PIPE WORK IS IN MEDIUM GRADE STEEL, ALL HORIZONTAL PIPEWORK IS TO RISE TO VENT.

EXPANSION BELLOWS AND ANCHORS ARE NOT SHOWN HOWEVER ARE REQUIRED AND MUST BE ALLOWED FOR AS PER QUOTATION FROM SPECIALIST.

FOR CONTINUATION INTO DWELLINGS, PLEASE REFER TO THE INTERNAL HEATING SCHEMATIC.

FOR CONTINUATION INTO COMMERCIAL UNITS, PLEASE REFER TO COMMERCIAL UNIT TERMINATION DETAIL.

HEATING RISER CUPBOARDS ARE TO BE VENTILATED BETWEEN LEVELS AND TO EXTERNAL AT THE TOP.

ALL PIPEWORK HIGH POINTS ARE TO BE VENTILATED AND LOW POINTS ARE TO BE FITTED WITH DRAIN OFF COCKS.

NOTE: ALL PIPE WORK AND FITTINGS TO BE INSULATED AS PER THE SPECIFICATION. GENERALLY WITH THE FOLLOWING MINIMUM THICKNESS:

PIPE SIZE (mm)	MIN. INSULATION THICKNESS	
	MINERAL WOOL (mm)	PHENOLIC FOAM (mm)
15	30	15
20	30	15
25	35	20
32	35	20
40	35	20
50	40	25
65	40	25
80	40	25
100	45	25
125	45	30
150	45	30
200	50	30
250	50	30

Rev	Date	Description	Drwn	Chkd
C1	01.06.2021	Construction Issue	DALS	EJ

Current purpose: CONSTRUCTION — Scale: NTS — Size: A0
Original issue Date: 01.06.2021 — Drwn: DALS — Chkd: EJ

WHITECODE DESIGN ASSOCIATES
BUILDING SERVICES DESIGN CONSULTANTS
26-27 The Hill, Northfleet
Gravesend, Kent, DA11 9EU
www.whitecode.co.uk
T: 01322 289977 E: design@whitecode.co.uk

Title:
HEATING DISTRIBUTION SCHEMATIC
MEWS AND ANNEX
SHEET 2 OF 2

Project:
HORNSEY
TOWN HALL

Client:
ARDMORE

Dwg Number:
10687-M-04-M-0001(2)

Rev:
C1

Saved: p:\10687_hornsey town hall\02_wda design info\01_drawings\m-e_mechanical schematics\10687-m-04-m-0001_mews & annex heating distribution schematic.dwg