

DESIGN AND ACCESS STATEMENT

PREPARED FOR

88 High Street, N8 7NU

Architecture Shop

69 Dunsmure Road, N16 5PT, London

www.architecture-shop.co.uk

DESIGN AND ACCESS STATEMENT

This application seeks to legalise the recent installation of the supply air fan and duct to Tomo Pizzeria commercial kitchen.

The new supply air fan and duct were installed recently following the extension of the restaurant kitchen (HGY/2016/2655). The carbon monoxide build up was getting very close to the allowed maximum level and the additional ventilation measures were agreed with gas and ventilation engineers to mitigate the issue. The letter from the engineer regarding the installed system is attached on the next page.

The new system supports the existing ventilation duct, which was a part of the extension works and which received planning permission on 29/09/2016 for planning application number HGY/2016/2655. Drawing P_04 of the current application shows the extent of the main ventilation duct agreed in 2016.



New supply air fan and duct

EWM ENTERPRISES

Gas and ventilation engineers

42 Napier Avenue
Southend-On-Sea
Essex
SS1 1LZ
07488366465
ewmengineers@yahoo.co.uk

FOR:

Tomo Pizzeria
88 High St
London
N8 7NU

September 2022

Dear Adam,

With reference to our telephone conversation, please find the details you requested regarding the installation of the supply air fan and duct to your commercial kitchen as required by DW172 to help reduce any build-up of carbon dioxide and carbon monoxide. The duct itself is a 250mm spiral duct, approximately 1m long. A system air AR sileo 250mm fan, a filter box with filter and a bird beak grill as termination.

As you know, the installation is very small, but it meets all the relevant ventilation and gas regulations.

Kind Regards,

Will.

