



Client:
LB Haringey

GENERAL NOTE:
This drawing is to be read in conjunction with all other drawings, structural, mechanical & electrical engineer's drawings. Written dimensions take precedence over scaled. All dimensions to be confirmed on site. All areas and dimensions are approximate and subject to change. All details are indicative of design intent. Specialist design subcontractors are to develop and co-ordinate final details for the contract administrators comments. All installations are to be in accordance with manufacturers recommendations, any discrepancy is to be notified to the contract administrator immediately. The Curtis Ltd. accept no responsibility for the accuracy of the existing building survey upon which these drawings are based. This drawing is protected by copyright and must not be copied or reproduced without the written consent of Kiran Curtis Ltd.

Notes:

DESIGN FREEZE

K	L	22.09.13	Issued for Information	MB	KC
K	K	28.08.05	Revised Risers	MB	KC
J	J	22.07.04	Issued for Design Freeze	MB	KC
I	I	18.05.22	Issued for information	JS	MB KC
H	I	19.04.22	WIP for Planning	JS	CM
G	H	03.04.22	PIP Application 3	JS	JAS CM
F	F	23.03.22	WIP for Planning	JS	JAS CM
E	E	22.01.26	Issued for information	MB	CM
D	D	21.12.06	Issued for Information	MB	CM
C	C	21.09.09	Stage 2 Pre-app Design Freeze	MB	WO CM
B	B	28.08.27	Issued for Pre-Application		WO
A	A	21.08.02	Issued for information	MB	WO CM
		21.07.29	Issued for Information	MB	WO CM
REV	DATE		DESCRIPTION		DWN CHK

Project:
0552 - Brunel Walk

Drawing Title:
Proposed 1st Floor Plan - Full Site

Drawing Number:
PL_1002

Scale: 1 : 250 Paper Size: A1 Revision: L

KC+A

Designing Brighter Futures
Architecture Urban Design Planning

+44 (0)20 7336 0999
enquiries@kcaarchitects.co.uk
www.kcaarchitects.co.uk

Temp House
62 - 160 City Road
London EC1V 2NX



FIRE SAFETY KEY (Floor Plans)

- 30 minute fire rated construction (P.E.S.)
- 60 minute fire rated construction (P.E.S.)
- Escape route
- Protected Lobby with 1.5m AOV
- Natural Smoke Shaft - 1.5m AOV
- Roof/Garage mounted permanent ventilation - 1.5m AOV
- Roof mounted permanent ventilation - 1.5m AOV
- Dry Riser Outlet
- FD 100
- FD 300
- FD 30
- Provision of Clearly Marked

1. Dry riser shall be provided for the protected stair in Block D2.

2. Please confirm the function of this room.

Note: Where bathrooms open directly into the protected entrance hall enclosure one of the preceding options should be adopted:

1.) The ventilation ductwork serving the bathrooms that connect with the entrance hall would either need to only ventilate that space and not any other spaces within the apartment - and the bathroom would need the compartmentation extended around the walls to act as an extension to the protected entrance hallway; or

2.) The bathroom would need to be fire separated from the protected entrance hall and the ventilation ductwork could then serve that space and other spaces within the apartment (excluding the protected entrance hall).

1 Proposed 2nd Floor Plan - Full Site
1 : 250

Client:
LB Haringey

GENERAL NOTE:
This drawing is to be read in conjunction with all other drawings, structural, mechanical & electrical engineer's drawings. Written dimensions take precedence over scaled. All dimensions to be confirmed on site. All areas and dimensions are approximate and subject to change. All details are indicative of design intent. Specialist design subcontractors are to develop and co-ordinate final details for the contract administrators comments. All installations are to be in accordance with manufacturers recommendations, any discrepancy is to be notified to the contract administrator immediately. Kiran Curtis Ltd. accept no responsibility for the accuracy of the existing building survey upon which these drawings are based. This drawing is protected by copyright and must not be copied or reproduced without the written consent of Kiran Curtis Ltd.

Notes:

DESIGN FREEZE

L	22.09.13	Issued for Information	MB	KC
K	22.09.06	Revised Risers	MB	KC
J	22.07.04	Issued for Design Freeze	MB	KC
I	18.05.22	Issued for Information	JS	MB
H	19.04.22	WIP for Planning	JS	CM
G	01.04.22	Pre Application 3	JS	JAS
F	23.03.22	WIP for Planning	JS	JAS
E	22.01.20	Issued for Information	MB	CM
D	21.12.06	Issued for Information	MB	CM
C	21.09.09	Stage 2 Pre-App Design Freeze	MB	WO
B	21.08.27	Issued for Pre-Application	WO	
A	21.08.02	Issued for Information	MB	WO
I	21.07.29	Issued for Information	MB	WO
REV	DATE	DESCRIPTION	DWN	CHK

Project:
0552 - Brunel Walk

Drawing Title:
Proposed 2nd Floor Plan - Full Site

Drawing Number:
PL_1003

Scale: 1 : 250
Paper Size: A1
Revision: L

KC+A

Designing Brighter Futures
Architecture Urban Design Planning

+44 (0)20 7336 0999
enquiries@kcaarchitects.co.uk
www.kcaarchitects.co.uk

Kemp House
152 - 160 City Road
London EC1V 2NX