

17/10/2022

Planning Department of London Borough of Haringey – Planning Service
Level 6
River Park House
Wood Green
N22 8HQ
United Kingdom

To whom it may concern,

RE: Omission of rear access to Blocks A2 and A3

This letter serves to support the NMA submission for Plot A of the High Road West development, otherwise known at Whitehall Mews.

The fire strategy for Blocks A2 and A3 of the High Road West development has been revised to align with the omission of the rear access to the gardens of the duplex units. The internal planning of these duplexes is aligned with the applicable guidance in BS 9991:2015, which is the basis of design for Blocks A2 and A3. Furthermore, this aspect of the fire strategy has been agreed with the Building Control Officer.

Regards,



Mark Norris
Fire Engineer | London

+44 773 249 9518
Mark.Norris@ofrconsultants.com

OFRCONSULTANTS.COM 