

From: **Albert Grant** <Albert.Grant@camden.gov.uk>
Date: Wed, 19 Oct 2022 at 14:33
Subject: RE: 181 Cranley Gardens - 2nd Floor flat
To: darek Fordon <qualitixbc@gmail.com>
Cc: Building.Control <Building.Control@camden.gov.uk>

Darek,

Re: 181 Cranley Gardens - 2nd Floor flat

Ref: 20/PI/06355

The Building Act 1984 and the Building Regulations

LABC EPAS

We can confirm the following:

The bedroom is an 'inner-room' that requires fire protection from the outer room, which is the living/dining area.

The partition alterations to the flat were required for fire safety requirements i.e. the kitchen area of the 'open-plan flat' required to be enclosed.

The size of the flat has not changed by the addition of the kitchen partition.

Regards,

Albert Grant BEng MEng
Principal Building Control Officer
Place Management
Supporting Communities
London Borough of Camden

Telephone: 020 7974 2396
Mobile: 07775564557
Fax: 020 7974 5603
Web: camden.gov.uk

2nd Floor
5 Pancras Square
5 Pancras Square
London N1C 4AG

