

James Argles

Subject: FW: Internal Consultation - App ref HGY/2022/2723

Sent: 24 October 2022 09:50

Subject: RE: Internal Consultation - App ref HGY/2022/2723

Hi James (Valerie)

Thank you for sending the details of this development at Brunel Walk, London N15 5HQ for review and comment.

I've looked at the proposals and my initial comments are that the refuse capacity outlined in the DAS is slightly lower than what we would expect, so bin numbers should be rounded up rather than down. My calculations for the new development estimate that there should be at least:

- 8 x 1,100 litres refuse eurobins
- 5 x 1,100 litres recycling eurobins
- 6 x 140 litres food waste wheelie bins

There was also reference in the DAS, of using the existing chute facilities but I wasn't clear about how that capacity was apportioned to the new development and whether that offset's some of the container calculations. The drag distances of bins from the bin store to the point of collection should not exceed 10m but Block A shows a 15m distance. This should be reviewed and the developers may also find it useful to consider space in the domestic bin store for bulky waste.

If helpful, I would be willing to meet the developers to discuss the refuse arrangements so that we are clear about the proposals.

Kind regards

Ann