

James Argles

From: Planning Support
Subject: FW: 7039 Welbourne - NMA Application Requirements - Brick & Mortar Specification at Ground Floor Level

HGY/2022/2581

From: Jack Goulde
Sent: 08 November 2022 15:34
Subject: RE: 7039 Welbourne - NMA Application Requirements - Brick & Mortar Specification at Ground Floor Level

Yes and in fact as ULS had spare bricks they will be from the same batch as the ones on the main building.

Kind Regards

Jack
Project Manager
Placemaking and Housing
Housing Delivery
Haringey Council
5th Floor Alexandra House, 10 Station Road, Wood Green N22 7TR

From: Richard Truscott
Sent: 08 November 2022 15:33
Subject: RE: 7039 Welbourne - NMA Application Requirements - Brick & Mortar Specification at Ground Floor Level

That looks *much* improved and now just about acceptable! Particularly it is really pleasing that it will exactly line up with the width of the main building and that the “panels” of hit & miss brickwork will roughly match the pattern of fenestration & piers of the main building. Can I just confirm that the proposed brick, mortar & jointing; Nelissen Wijnegem with Euromix Natural Harlow mortar (recessed joint), is the same as on the ground floor of the rest of the Welbourne? If so, I would say that is absolutely fine!

Regards

Richard Truscott
Design Officer
Placemaking and Housing, Haringey Council, 40 Cumberland Road, London N22 7SG