



LEGEND

- Lighting bollard
- 6M Lighting column
- Tree uplighter
- LED Spigot light within hand rail
- LED strip light within decking edge
- Underground Duct
- Connection / junction box

NOTES


- All lighting columns to have integrated COBO projectors and security cameras to provide consistent coverage between columns.
Final number for CCTV & GOBO projector t.b.c.
- All ducts are to be installed a minimum of 1 meter from trees.

LUMINAIRE SCHEDULE

A	HESS LIGHTING LICHTPOLLER CITY ELEMENTS 180-PAA 3000K TYPE 1 12w PLEASE NOTE DRIVER IS LOCATED WITHIN THE BOLLARD.
B	HESS LIGHTING LICHTPOLLER CITY ELEMENTS 180-PAA 3000K TYPE 1 12w INSTALLED WITH SHIELDED BOLLARD. PLEASE NOTE DRIVER IS LOCATED WITHIN THE BOLLARD.
C	HESS LIGHTING TOP ELEMENT 200-2 AR HP 3000K TYPE 1 50w PLEASE NOTE DRIVER IS LOCATED WITHIN COLUMN.
D	ORLIGHT LINEAR STRIP INSTALLED WITHIN FLOOR. PLEASE NOTE DRIVER IS LOCATED LOCALLY IN CONNECTION BOX.
E	ORLIGHT LINEAR STRIP INSTALLED WITHIN HAND RAIL. PLEASE NOTE THE DRIVER IS LOCATED WITHIN THE HANDRAIL.
F	ORLIGHT TREE UPLIGHTER. PLEASE NOTE DRIVER IS LOCATED LOCALLY IN CONNECTION BOX.

Lux Levels:

- 5 Lux
- 10 Lux
- 20 Lux
- 30 Lux
- 50 Lux



Copyright
This drawing is copyright and may not be altered, reproduced or used other than for the
Contract Works for which it is issued without the written permission of Foreman Roberts.
Status of drawing
The purpose of this drawing when issued as a Tender Drawing is to provide tenders to
prepare correctly the design and to make comparison notes to the works.
A Tender Drawing whether original or amended shall not be used as an instruction drawing
except under the terms contained in the conditions of Tender.
Warning
Do not scale this drawing. Verify all dimensions and structural details on site. If in doubt,
ask before fixing.
Related documents
This drawing is to be read in conjunction with the appropriate Specification(s).
Checking
This drawing has been generated using a Computer Aided Drafting system. As the
system generates a new drawing at each revision, only the latest revision will have been
checked or plotted.

C2	Issued for Construction Updated to incorporate lighting to the front of Shop 02 and provide new driveway kerbsides.	19.11.20	AF	GP
C1	Issued for Construction Client's Design Team comments incorporated into specification.	14.08.20	LSE	GP
P5	P1-Transfer issues	22.07.20	EE	GP
P4	P2-Information - Components added and deleted; quantities amended	24.06.20	AF	GP
P3	P2-Information - Lux levels updated and manufacture information added	15.06.20	AF	GP
P2	P2-Information - Lux levels added	17.03.20	AF	GP
P1	P2-Information	04.03.20	EE	GP
Rev	Details	Date	Drawn	Chk'd
Client				

St William
Designed for life

Consultant
Building Services Consultants
Gordon Street, Newcastle, NSW
www.foremanroberts.com
Phone: 08 9550 1111 Fax: 08 9550 1111
Email: info@foremanroberts.com.au

Clarendon Road Phase 3A FRC Project No.
L14796

External Lighting Sheet 2 of 2

Scale @A0 Status Revision
1:100 For Construction C1

Project Code: Designer Zone Level Type Date: Drawn Number
W227-FRC-DD-00-DR-E-96-0002