

Based on drawings by Grant Associates
TH-IS-03-001-LA-TOT494-(90)-1305 REV01

To be read in conjunction with
TH-IS-03-001-L-1264-90-100

Concrete: Exposed natural stone aggregate finish 'Silver with silver grey granite' (TBC)
Concrete minimum strength C25/30, mix to be confirmed by installer
build up in no more than 300mm layers (to be agreed with site engineer)

Foundations:


Concrete foundations shall be to BS 8500-1 & -2:2006 and BS EN 206-1, designated mix G1 or Standard mix S12. Dimensions of concrete foundations to be advised by a structural engineer following ground investigation.

Damp proof course:

Damp proof course shall be polymer sheet. To be the full thickness of wall and flush with face. At joints of polymer sheets, overlap the preceding roll by at least 400mm. To be placed not less than 150mm above the ground level.

Plan to be read in conjunction with the engineer and landscape drawings. All dimensions and levels to be checked on site and against engineers drawings.

No measurements to be scaled off drawing. Worked from figured dimensions only. All dimensions shown on drawing are shown in millimetres unless otherwise stated.



Arborterra Ltd