



MCS 020 noise assessment

Heat pump property: 71 Connaught Gardens, London, N10 3LG

Neighbour property: 73 Connaught Gardens, London, N10 3LG

Type of room: Bedroom

Step		Result
1	Sound Power	60
2	Directivity	4
3	Distance	8
4	dB distance reduction	-23
5	Solid Barrier	0
6	Sound Pressure Level	37
7	Background Noise Level	40
8	Difference	3
9	Decibel Correction	41.8
10	Final Result	42.0

Assessment date: 04/01/2023

Assessor: Tomas Larsson, Director