

Mrs Maha Phillips
Haines Phillips Architects
Tankerton Works
12 Argyle Walk
London
WC1H 8HA

6 February 2023

**TOWN AND COUNTRY PLANNING ACT 1990
TOWN AND COUNTRY PLANNING (DEVELOPMENT MANAGEMENT PROCEDURE)
(ENGLAND) ORDER 2015
NOTICE OF PLANNING PERMISSION**

Case Reference HGY/2022/4394
Location 8 Farrer Road, Hornsey, London, N8 8LB
Proposal Erection of an enclosure for an air-conditioning unit (serving the house) in the rear garden.
Received 12 December 2022

In pursuance of their powers under the above Act, the London Borough of Haringey as Local Planning Authority hereby PERMIT the above development received on the above date.

Title	Description	Date
4285-GA 310 PL 2.pdf	Block plan of the site	12 December 2022
4285-GA 110 PL 1.pdf	Site/Block Plan - Existing	12 December 2022
4285-GA 122 PL 1.pdf	Elevation (Rear) - Existing	12 December 2022
4285-GA 101 PL 1.pdf	The location plan	12 December 2022
4285-GA 120 PL 1.pdf	Section - Existing	12 December 2022
4285-GA 322 PL 1.pdf	Additional plans	12 December 2022
4285-GA 320 PL 2.pdf	Section - Proposed	12 December 2022

Robbie McNaugher

Robbie McNaugher
Head of Development Management and Planning Enforcement
Planning Service

Conditions: (4)

- 1 The development to which this permission relates must be begun no later than three years from the date of this decision notice, failing which the permission shall be of no effect.

Reason: This condition is imposed by virtue of Section 91 of the Town and Country Planning Act 1990 and to prevent the accumulation of unimplemented planning permissions.

- 2 The development hereby permitted shall be carried out in complete accordance with the approved plans and drawings listed in this decision notice, other than where those details are altered pursuant to the conditions of this planning permission.

Reason: For the avoidance of doubt and in the interests of proper planning.

- 3 The noise level from the operation of the air source heat pump hereby approved must not exceed 42dB LAeq (5 min) at 1 metre from the window of a habitable room on the façade of any neighbouring residential property. If, in the opinion of the Local Planning Authority the proposed air source heat pump result in any noise nuisance to the occupant of any neighbouring dwelling the Applicant shall install noise mitigation measures in agreement with the Planning Authority.

Reason: The level of noise from the air conditioning unit is, so far as practicable kept to a minimum so as to minimize its effect on the amenity of the surrounding properties and general area. In order to protect the amenities of nearby residential occupiers consistent with Policy D14 of the London Plan 2021 and Policies DM1 and DM23 of The Development Management DPD 2017.

- 4 All plant and equipment shall be supported on adequate proprietary anti-vibration mounts as necessary to prevent the structural transmission of vibration and regenerated noise within adjacent or adjoining premises, and these shall be so maintained thereafter. If at any time the plant is unable to comply with this Condition, it shall be switched off and not used again until it is able to comply.

Reason: . In order to protect the amenities of nearby residential occupiers consistent with Policy D14 of the London Plan 2021 and Policies DM1 and DM23 of The Development Management DPD 2017.

Informatives:

INFORMATIVE: Hours of Construction Work

The applicant is advised that under the Control of Pollution Act 1974, construction work which will be audible at the site boundary will be restricted to the following hours:-

8.00am - 6.00pm Monday to Friday
8.00am - 1.00pm Saturday
and not at all on Sundays and Bank Holidays.

INFORMATIVE: Party Wall Act

The applicant's attention is drawn to the Party Wall Act 1996 which sets out requirements for notice to be given to relevant adjoining owners of intended works on a shared wall, on a boundary or if excavations are to be carried out near a neighbouring building.

- 1 You can find advice in regard to your rights of appeal at:
www.planningportal.gov.uk/planning/appeals/guidance/guidancecontent
- 2 This notice relates solely to a planning decision and does not purport to convey any approval or consent which may be required under the Building Regulations or any other statutory purpose.
If you intend to submit an appeal that you would like examined by inquiry then you must notify the Local Planning Authority and Planning Inspectorate (inquiryappeals@planninginspectorate.gov.uk) at least 10 days before submitting the appeal.
- 3 For more information about making a Building Regulations application, please contact Haringey Council Building Control Team by email building.control@haringey.gov.uk, telephone 020 8489 5504, or see our website at www.haringey.gov.uk/buildingcontrol.