

Kwaku Bossman-Gyamera

From: Roger Molyneux <rm@molyarch.co.uk>
Sent: 14 February 2023 11:03
To: Kwaku Bossman-Gyamera
Cc: Mark Glock; Matt Paddock; Stephen Reynolds; David Mayell
Subject: Re: FW: Condition on Planning Application HGY/2022/4287 at St John's Church and Hall, Acacia Avenue, London, N17 8LR, London
Attachments: Subsoil Nov 22.pdf; Multi Purpose Topsoil Nov 2022.pdf

Dear Kwaku;

Thank you for your email of yesterday. Obviously it is not the decision that we wanted but we will progress as required.

Taking each of the points in turn.

1. Requirement: Dig down to 600mm across the private garden areas. Remove all soil. Picture / reference depth and evidence of this depth has been achieved.

Response: The picture/reference depth record will be achieved by using a horizontal string at hard paving level and a series of photographs taken and recorded on a plan.

2. Requirement: Refill with clean soil – need for evidence that it is clean when brought to site.

Response: Attached is the chemical makeup of the top soil and subsoil that we proposes to use. Matt Paddock of Geo-Engineering has confirmed that it meets your requirements.

3. Requirement: Sample of the new soil in situ (at depth of 400mm / 500m), one sample per garden, to ensure it has not been

contaminated during transport / installation. Need a verification table showing depth etc. Photos required of the verification pits.

Response: Because of our need to complete before the end of the month, you will have to trust us as soil testing will take at least 3-4 days to implement. As with item 1 above, picture/reference depth record will be achieved by using a horizontal string at hard paving level and a series of photographs taken and recorded on a plan.

4. Requirement: The communal areas are okay to remain.

Response: Thank you. We have two very small private outdoor areas at the rear of two of the houses. They receive no sunlight.

We propose to hard pave these areas on sand and geotextile membrane. Can you please confirm by return that this is acceptable.

With best wishes;

Roger M

+ **MOLYNEUX** ARCHITECTS

181 Union Street, London , SE1 0LN

Tel. (44) 020 7021 0411

www.molyarch.co.uk

On Mon, 13 Feb 2023 at 12:35, Kwaku Bossman-Gyamera <Kwaku.Bossman-Gyamera@haringey.gov.uk> wrote:

Dear, Roger

Having discussed the options we feel the only way forward to ensure residents are not put at risk and satisfy colleagues is to-

1. Dig down to 600mm across the private garden areas. Remove all soil. Picture / reference depth and evidence of this depth has been achieved.
2. Refill with clean soil – need for evidence that it is clean when brought to site.
3. Sample of the new soil in situ (at depth of 400mm / 500m), one sample per garden, to ensure it has not been contaminated during transport / installation. Need a verification table showing depth etc. Photos required of the verification pits.
4. The communal areas are okay to remain.

Regards

Kwaku Bossman-Gyamera

Principal Planning Officer - Development Management

Haringey Council

River Park House, 255 High Road, Wood Green, London N22 8HQ

T. 020 8489 5627

M.07989134742

E. kwaku.bossman-gyamera@haringey.gov.uk

www.haringey.gov.uk

[twitter@haringeycouncil](https://twitter.com/haringeycouncil)

facebook.com/haringeycouncil

Please note the above opinion represents informal officer observation only, offered without prejudice to all future formal Council decisions and accompanying procedures



From: Kwaku Bossman-Gyamera <Kwaku.Bossman-Gyamera@haringey.gov.uk>

Sent: 13 February 2023 12:11

To: Robbie McNaugher <Robbie.McNaugher@haringey.gov.uk>

Subject: RE: Condition on Planning Application HGY/2022/4287 at St John's Church and Hall, Acacia Avenue, London, N17 8LR, London

Good morning Robbie

Following Joes comments below. Should forward the comments to the agent? Or wait for us to discuss first.

Please advise – Thanks

Regards

Kwaku Bossman-Gyamera

From: Joe Baker <Joe.Baker@haringey.gov.uk>

Sent: 10 February 2023 12:07

To: Robbie McNaugher <Robbie.McNaugher@haringey.gov.uk>; Kwaku Bossman-Gyamera <Kwaku.Bossman-Gyamera@haringey.gov.uk>

Cc: Edward Ritchie <Edward.Ritchie@haringey.gov.uk>

Subject: Condition on Planning Application HGY/2022/4287 at St John's Church and Hall, Acacia Avenue, London, N17 8LR, London

Robbie / Kwaku

This is a dog's dinner!

This is what they need to do.

1. Dig down to 600mm across the private garden areas. Remove all soil. Picture / reference depth and evidence of this depth has been achieved.
2. Refill with clean soil – need for evidence that it is clean when brought to site.
3. Sample of the new soil in situ (at depth of 400mm / 500m), one sample per garden, to ensure it has not been contaminated during transport / installation. Need a verification table showing depth etc. Photos required of the verification pits.
4. The communal areas are okay to remain.

If you are happy with this, I am happy for you to forward this on to them.

Regards,

Joe Baker - Head of Carbon Management

T: 020 8489 3976

E: joe.baker@haringey.gov.uk



You can visit our [Going Green pages](#) to read Haringey's Climate Change Action Plan to get to a Net Zero Carbon Borough by 2041

This email and any files transmitted with it are confidential, may be subject to legal privilege and are intended only for the person(s) or organisation(s) to whom this email is addressed. Any unauthorised use, retention, distribution, copying or disclosure is strictly prohibited. If you have received this email in error, please notify the system administrator at Haringey Council immediately and delete this e-mail from your system. Although this e-mail and any attachments are believed to be free of any virus or other defect which might affect any computer or system into which they are received and opened, it is the responsibility of the recipient to ensure they are virus free and no responsibility is accepted for any loss or damage from receipt or use thereof. All communications sent to or from external third party organisations may be subject to recording and/or monitoring in accordance with relevant legislation.

--

With best wishes;
Roger M

+ MOLYNEUX ARCHITECTS
181 Union Street, London , SE1 0LN
Tel. (44) 020 7021 0411
www.molyarch.co.uk