

James Argles

Subject: FW: Re: Discharge of Condition Planning Application HGY/2022/4312 at Former Red House Care Home, 423 West Green Road, Tottenham, London, N15 3PJ

Sent: Thursday, February 9, 2023 3:11 PM

Subject: RE: Re: Discharge of Condition Planning Application HGY/2022/4312 at Former Red House Care Home, 423 West Green Road, Tottenham, London, N15 3PJ

Dear Chris,

Re: Discharge of Condition Planning Application HGY/2022/4312 at Former Red House Care Home, 423 West Green Road, Tottenham, London, N15 3PJ

Thanks for re-contacting the Carbon Management Team (Pollution) regarding the discharge of condition 15 (boilers) attached to planning permission HGY/2018/1806 and I would like to comment as follows.

Having considered the applicant proposal to install: 1No Strebel S-CBX 155 Boiler with NOx Level (Dry @ 0% O2) of 20.1mg/kWh, 3No Strebel S-CBX 105 Boilers with NOx Level (Dry @ 0% O2) of 21.3mg/kWh and 5No Strebel S-CBX 125 Boilers with NOx Level (Dry @ 0% O2) of 23.9mg/kWh from the submitted stainless steel range of condensing boilers, **we are satisfied with the discharge of attached condition 15 (boilers) of the approved planning permission HGY/2018/1806.**

I hope the above clarify our position on the submitted application? Otherwise, feel free to contact us should you have any further query in respect of the application.

Kind Regards,

Edward Ritchie
Pollution Officer

Haringey Council
Carbon Management
5th Floor, Alexandria House
Station Road
Wood Green
N22 7TY