

Ben Coffie
London Borough of Haringey
Development Control
639 High Road
London
N17 8BD

Our ref: NE/2023/135504/01-L01
Your ref: HGY/2023/0180
Date: 27 March 2023

Dear Ben

Redevelopment of the existing petrol filling station to provide an EV charging hub including charging bays, canopy above, extension of existing amenity building and associated development

Petrol Filling Station, Pinkham Way, Wood Green, London, N11 2UU

Thank you for consulting us on the above application.

We have no objection based on the current proposal on flood risk grounds and recommend the following advice.

Advice to Local Planning Authority & applicant

Flood resistance and resilience

We strongly recommend the use of flood resistance and resilience measures. Physical barriers, raised electrical fittings and special construction materials are just some of the ways you can help reduce flood damage.

To find out which measures will be effective for this development, please contact your building control department. In the meantime, if you'd like to find out more about reducing flood damage, visit the Flood Risk and Coastal Change pages of the planning practice guidance. The following documents may also be useful:

Department for Communities and Local Government: Preparing for floods
<http://www.planningportal.gov.uk/uploads/odpm/4000000009282.pdf>

Department for Communities and Local Government: Improving the flood performance of new buildings: <https://www.gov.uk/government/publications/flood-resilient-construction-of-new-buildings>

Emergency access and egress

The following issues are not within our direct remit or expertise, but nevertheless are important considerations for managing flood risk for this development. Prior to deciding this application, we recommend that consideration is given to the issues below. Where necessary, the advice of relevant experts should be sought.

Cont/d..

- Adequacy of rescue or evacuation arrangements
- Details and adequacy of an emergency plan
- Provision of and adequacy of a temporary refuge
- Details and adequacy of flood proofing and other building level resistance and resilience measures
- Details and calculations relating to the structural stability of buildings during a flood
- Whether insurance can be gained or not
- Provision of an adequate means of surface water disposal such that flood risk on and off-site isn't increased

Signing up for flood warnings

The applicant/occupants should phone Floodline on 0345 988 1188 to register for a flood warning, or visit <https://www.gov.uk/sign-up-for-flood-warnings>. It's a free service that provides warnings of flooding from rivers, the sea and groundwater, direct by telephone, email or text message. Anyone can sign up.

Flood warnings can give people valuable time to prepare for flooding – time that allows them to move themselves, their families and precious items to safety. Flood warnings can also save lives and enable the emergency services to prepare and help communities.

For practical advice on preparing for a flood, visit <https://www.gov.uk/prepare-for-flooding>.

To get help during a flood, visit <https://www.gov.uk/help-during-flood>.

For advice on what to do after a flood, visit <https://www.gov.uk/after-flood>.

Please let me know if you have any questions.

Yours sincerely

Deborah Simons
Planning Advisor

Direct e-mail HNLsustainablePlaces@environment-agency.gov.uk