

Mr Jez Gay
26 The Avenue
London
United Kingdom
N8 0JR

21 April 2023

**TOWN AND COUNTRY PLANNING ACT 1990
TOWN AND COUNTRY PLANNING (DEVELOPMENT MANAGEMENT PROCEDURE)
(ENGLAND) ORDER 2015
NOTICE OF PLANNING PERMISSION**

Case Reference HGY/2023/0012
Location 34 The Avenue, Hornsey, London, N10 2QL
Proposal Erection of a single storey rear extension and rear outbuilding,
and installation of PV panels on roof, heat pump and external
insulation (AMENDED PLANS).
Received 4 January 2023

In pursuance of their powers under the above Act, the London Borough of Haringey as Local Planning Authority hereby PERMIT the above development received on the above date.

Title	Description	Date
Noise Impact Assessment.pdf		4 January 2023
L_001 Location.pdf	The location plan	4 January 2023
L_100 Existing.pdf	Existing drawings	4 January 2023
L_300 DAS.pdf	Design and access statement	4 January 2023
L_400 Heritage.pdf	Heritage statement	4 January 2023

Robbie McNaugher

Robbie McNaugher
Head of Development Management and Planning Enforcement
Planning Service

Conditions: (4)

- 1 The development to which this permission relates must be begun no later than three years from the date of this decision notice, failing which the permission shall be of no effect.

Reason: This condition is imposed by virtue of Section 91 of the Town and Country Planning Act 1990 and to prevent the accumulation of unimplemented planning permissions.

- 2 The development hereby permitted shall be carried out in complete accordance with the approved plans and drawings listed in this decision notice, other than where those details are altered pursuant to the conditions of this planning permission.

Reason: For the avoidance of doubt and in the interests of proper planning.

- 3 The noise level from the operation of the air source heat pump hereby approved must not exceed 42dB LAeq (5 min) at 1 metre from the window of a habitable room on the façade of any neighbouring residential property. If, in the opinion of the Local Planning Authority the proposed air source heat pump result in any noise nuisance to the occupant of any neighbouring dwelling the Applicant shall install noise mitigation measures in agreement with the Planning Authority.

Reason: In order to protect the amenities of nearby residential occupiers consistent with Policy D14 of the London Plan 2021 and Policies DM1 and DM23 of The Development Management DPD 2017.

- 4 The garden room hereby approved shall not be occupied at any time other than for purposes incidental to the residential use of the residential dwelling 34 The Avenue and shall not be used as an independent dwelling or for commercial purposes, without the prior approval in writing of the local planning authority.

Reason: In the interests of the amenities of the area and to comply Local Plan 2017 Policy SP2 which set out appropriate standards and requirements for all new dwellings.

Informatives:

INFORMATIVE: Outbuildings and Building Regulations

Your attention is drawn to the need to comply with the relevant provisions of Building

Regulations which can apply in relation to certain outbuildings in terms of size, use and proximity to a boundary. Please refer to the following for further advice.

https://www.planningportal.co.uk/info/200130/common_projects/43/outbuildings/

<https://www.haringey.gov.uk/planning-and-building-control/building-control>

INFORMATIVE: Hours of Construction Work

The applicant is advised that under the Control of Pollution Act 1974, construction work which will be audible at the site boundary will be restricted to the following hours:-

8.00am - 6.00pm Monday to Friday

8.00am - 1.00pm Saturday

and not at all on Sundays and Bank Holidays.

- 1 You can find advice in regard to your rights of appeal at:
<https://www.gov.uk/appeal-householder-planning-decision>
- 2 This notice relates solely to a planning decision and does not purport to convey any approval or consent which may be required under the Building Regulations or any other statutory purpose.
If you intend to submit an appeal that you would like examined by inquiry then you must notify the Local Planning Authority and Planning Inspectorate (inquiryappeals@planninginspectorate.gov.uk) at least 10 days before submitting the appeal.
- 3 For more information about making a Building Regulations application, please contact Haringey Council Building Control Team by email building.control@haringey.gov.uk, telephone 020 8489 5504, or see our website at www.haringey.gov.uk/buildingcontrol.