



MCS 020 noise impact assessment for 261 Alexander Park Road

This assessment was done in relation to the neighbour window most likely to be affected by noise from the heat pump.

This is the result of the assessment:

Step	Instruction	Result
1	Sound power	60
2	Directivity Q	4
3	Distance	9
4	dB reduction	-25
5	Solid barrier	0
6	Sound pressure level	30
7	Background noise	40
8	Difference	10
9	Decibel correction	40
10	FINAL RESULT	PASS

Oliver Larsson

Better Planet UK Ltd



Prepared by Oliver Larsson, Better Planet UK LTD

Phone number: 07582 382589

Email: oliver.larsson@betterplanet.co.uk