



Condition A25: HGY/2023/0747 – Responses to LBH 05.05.23

LBH Comments 04.04.23	Responses
1. Photographic evidence confirming that the installation of Geotextile liners has been undertaken in areas of soft landscaping.	This is only applicable to the central planting area of the rear courtyard, please see evidence of Geotextile layer installed prior soil infill. The rear courtyard planters are formed in RC. There is concrete segregation from existing ground. Photos and technical details attached in Appendix 1, page 1.
2. Photographic evidence that the depth of the clean cover systems for areas of soft landscaping are no less than 600mm.	Clean cover evidence included on page two attached, a minimum cover of 600mm has been achieved.
3. While photographic evidence of the installed barrier pipe has been provided, we require confirmation from the Water Company that an appropriate barrier has been installed.	Please see specified pipe from Thames water highlighted in Appendix 2, HG installed barrier pipe as an enhancement to spec.

Appendix 1 – Geotextile Installation Images



Reinforcement Intent for New Walls inc 200mm New Base



Appendix 2 – Thames Water Barrier Pipe Specification



Clean Water

Site address: -, THE HALE, LONDON, N17 9JZ

New water connection quote

Your details:

Name: HG Construction Ltd

Address: 34--36 Grays Inn Road

Email: owenmcilreavy@hgconstruction.co.uk

Phone:

DS Reference: DS6088592

Quote number: 20115669

Date: 24 December 2021

Work Description: New Domestic/Commercial, 1x50mm MDPE Commercial Metered Supply, 1x90mm HPPE non-rev Metered Combined Fire Domestic Bulk Supply with 138x20mm internal fit meters, 1x125mm HPPE non-rev Metered Dedicated