

Daniel Kwasi

From: Shreekant Patel
Sent: 02 May 2023 22:21
To: Daniel Kwasi
Subject: HGY/2022/3997 - 11, St Pauls Road, Tottenham, London, N17 0NB

Hello Daniel,

Transport comments are as follows:

- a. The cycle storage enclosure would not provide sufficient space to allow each bicycle to be independently accessed. Each of the two bicycles adjacent to the side walls of storage enclosure would not be accessible without each of the two adjacent cycle in the middle of the storage being unoccupied. The proposal requires revision.
- b. The access to the cycle parking should not be obstructed by refuse bins in the front yard. A plan illustrating location of refuse storage bins should be provided to demonstrate access to cycle parking remains unobstructed.

Regards,

Shreekant Patel
Principal Transport Planner.

London Borough of Haringey,
Placemaking & Housing
Planning Policy, Transport and Infrastructure
Alexandra House (5th Floor)
Wood Green
London, N22 &TR

Tel.No: 020 8489 5740
Mobile: 07989224012
Email: Shreekant.patel@haringey.gov.uk