

Condition A25: HGY/2023/0747 – Responses to LBH 19.05.23

LBH Comments 15.05.23	Responses
1. 1. Photographic evidence that the depth of the clean cover systems for areas of soft landscaping are no less than 600mm. While we take note of the photographs on page 2 of the applicant submitted document, we do not consider them sufficient to determine the depth of the cover system. We would require additional photographs with a method of establishing depth/scale (measuring staff or tape) to be able confirm the depth of the imported soils - rather than with annotated arrows/measurements as currently submitted in the submitted document "Condition A25: HGY/2023/0747 – Responses to LBH" dated 5th May 2023. Therefore, additional photographic evidence is required.	Please see further photographic evidence demonstrating clean cover of around 900mm over the minimum depth of 600mm in Appendix 1.

Appendix 1 – Photographic Evidence

