

James Argles

Subject: FW: ENVIRONMENTAL NOISE IMPACT ASSESSMENT - HGY/2022/4476

Importance: High

Sent: Tuesday, May 23, 2023 6:30 PM

Subject: FW: ENVIRONMENTAL NOISE IMPACT ASSESSMENT - HGY/2022/4476

Dear Martin

I have reviewed the attached. I note that the calculated internal noise with windows open is 48dB $L_{Aeq, 8 \text{ Hour}}$ which is 18dB above the levels outlined in BS8233. Since this is only likely to be an issue for 1% of the time (and only then when external temperatures exceed 26degrees between 23:00 and 07:00 hours) I am of the opinion that this is an acceptable margin.

Yours sincerely

Jennifer Barrett
Noise and Nuisance Manager

Sent: Tuesday, May 23, 2023 5:56 PM

Subject: RE: ENVIRONMENTAL NOISE IMPACT ASSESSMENT - HGY/2022/4476

Hi Jen,

I've just been sent a further detail in relation to the need to open the windows. Can you have a quick look – I think its ok.

Kindest regards

Martin

Sent: Tuesday, May 23, 2023 4:18 PM

Subject: ENVIRONMENTAL NOISE IMPACT ASSESSMENT - HGY/2022/4476

Dear Martin

Environmental Noise Impact Assessment, External Glazing Report (HGY/2022/4476)

I have reviewed the noise assessment provided (reference: SA – 6685 GL01) as details pursuant to Condition A13 (Noise Level Testing Details) of the Tottenham Hale Centre planning permission.

I accept the specifications for provided for the ventilation and external glazing. I confirm that no further information is required and recommend the discharge of Condition A13.

Yours sincerely

Jennifer Barrett

