

NOTES

- Drawing to be read in conjunction with design risk management drawings
- For full distribution details including sizes and valve arrangements, please refer to relevant schematic.
- Pipe work running externally to be finished in PIB coating to prevent moisture ingress.
- This drawing shall be read in conjunction with the NBS Specification and all British Standards and documents referred to within the mechanical & electrical schematics, detail sheets, and relevant structural and architectural drawings.
- All heating to be installed in line with GTC technical guidelines.
- Incoming mains with the ground to be designed by GTC.
- Pipework entry into the apartment is to be detailed by the architect.

KEY

- F&R Flow and Return
FA From Above
FB From Below
TA To Above
TB To Below

FOR LOUVER REFERENCES, REFER TO FACADE LOUVER SCHEDULE 10687-M-08-0002

FOR ATTENUATION REFERENCES, REFER TO CAICE QUOTATION 886602/22/1 AND 886602/18/2

NOTE: C CONTRACTOR TO ALLOW FOR CHANGES TO LOCATIONS AND ROUTINGS OF SERVICES TO SUIT SITE CONDITIONS

NOTE: B SERVICE VOIDS TO BE SURVEYED ON SITE PRIOR TO PROCUREMENT & INSTALLATION TO ENSURE SERVICES CAN BE UNOBSTRUCTED IN SPACE

NOTE: A DRAWING IS CONSTRUCTION ISSUE PROVISIONALLY ONLY. EAST WING IS CURRENTLY THE ONLY AREA THAT HAS BEEN FULLY COORDINATED AND DETAILED WITH DESIGN TEAM

BACKGROUND PLAN AS PER: KDS ARCHITECTS			
Drawing No:	3670-KDS-TH-RF-DR-A-03-2006	Revision:	N/A
DATE RECEIVED:	26.10.2022		

Rev	Date	Description	Scale: 1:125	Size: A1
C10	16.03.2023	AHURF/02 moved back from ductwork to allow easier access as per L&P comments	Dwn: SV	Chkd: EJ
C9	08.02.2023	Updated to comments from site visit		
C8	27.09.2022	Updated to comments from site visit		
C7	05.08.2022	Updated as per latest site visit comments		
C6	22.03.2022	Updated to L&P comments		
C5	24.01.2022	Updated to Flakwood units		
C4	11.11.2021	VCD's added. Added AHURF/03		
C3	22.04.2021	Attenuation and weights updated. Provisional as per notes above		
C2	18.01.2021	Updated vent duct to fit in clay pot. Added attenuators to AHU's		
C1	05.11.2020	Construction issue. Provisional as per above note		
WIP	03.07.2020	Construction Issue		
Rev	Date	Description	Dwn: SV	Chkd: EJ

Current purpose: CONSTRUCTION
Original issue Date: 24.06.2020

WHITECODE CONSULTING
BUILDING SERVICES DESIGN CONSULTANTS
26-27 The Hill, Northfleet, Gravesend
Kent, DA11 9EU
www.whitecode.co.uk
T: 01322 289977 E: design@whitecode.co.uk

Title: VENTILATION LAYOUT TOWN HALL & HOTEL ROOF
Project: HORNSEY TOWN HALL
Client: ARDMORE
Dwg Number: 10687-V-02-TH-0103

Rev: C10

