

Mr. Anestis Skoupras
45
Circus Road
NW8 9JH

13 June 2023

**TOWN AND COUNTRY PLANNING ACT 1990
TOWN AND COUNTRY PLANNING (DEVELOPMENT MANAGEMENT PROCEDURE)
(ENGLAND) ORDER 2015
NOTICE OF PLANNING PERMISSION**

Case Reference HGY/2023/0908
Location Shop, 632 Lordship Lane, Wood Green, London, N22 5JH
Proposal Proposed installation of an extraction flue system to allow the
use of the shop as a restaurant.
Received 30 March 2023

In pursuance of their powers under the above Act, the London Borough of Haringey as Local Planning Authority hereby PERMIT the above development received on the above date.

Title	Description	Date
03001 - Existing & Proposed Plans & Elevations		30 March 2023
Silent Box Fan unit AMF-560/1 by Ventorn - Manufacturers Spec		30 March 2023
Mitigation Details (Mounted Silencers Document)		30 March 2023

Robbie McNaughton

Robbie McNaughton
Head of Development Management and Planning Enforcement
Planning Service

Conditions: (3)

- 1** The development to which this permission relates must be begun no later than three years from the date of this decision notice, failing which the permission shall be of no effect. Reason: This condition is imposed by virtue of Section 91 of the Town and Country Planning Act 1990 and to prevent the accumulation of unimplemented planning permissions.
- 2** The development hereby permitted shall be carried out in complete accordance with the approved plans and drawings listed in this decision notice, other than where those details are altered pursuant to the conditions of this planning permission. Reason: For the avoidance of doubt and in the interests of proper planning.
- 3** The design and installation of the extraction system hereby approved shall be such that, when in operation, the cumulative noise level LAeq 15 min arising from the proposed plant, measured or predicted at 1m from the facade of nearest residential premises shall be a rating level of at least 5dB(A) below the background noise level LAF90. The measurement and/or prediction of the noise should be carried out in accordance with the methodology contained within BS 4142: 1997. Upon request by the local planning authority a noise report shall be produced by a competent person and shall be submitted to and approved by the local planning authority to demonstrate compliance with the above criteria.

Reason: In order to protect the amenities of nearby residential occupiers consistent with Policy D14 of the London Plan 2021 and Policies DM1 and DM23 of The Development Management DPD 2017.

Informatives:

INFORMATIVE: Hours of Construction Work

The applicant is advised that under the Control of Pollution Act 1974, construction work which will be audible at the site boundary will be restricted to the following hours:-
8.00am - 6.00pm Monday to Friday
8.00am - 1.00pm Saturday
and not at all on Sundays and Bank Holidays.

INFORMATIVE: Party Wall Act

The applicant's attention is drawn to the Party Wall Act 1996 which sets out requirements for notice to be given to relevant adjoining owners of intended works on a shared wall, on a boundary or if excavations are to be carried out near a neighbouring building.

INFORMATIVE: Land Ownership

The applicant is advised that this planning permission does not convey the right to enter onto or build on land not within his ownership.

- 1 You can find advice in regard to your rights of appeal at:
<https://www.gov.uk/appeal-planning-decision>.
- 2 This notice relates solely to a planning decision and does not purport to convey any approval or consent which may be required under the Building Regulations or any other statutory purpose.
If you intend to submit an appeal that you would like examined by inquiry then you must notify the Local Planning Authority and Planning Inspectorate (inquiryappeals@planninginspectorate.gov.uk) at least 10 days before submitting the appeal.
- 3 For more information about making a Building Regulations application, please contact Haringey Council Building Control Team by email building.control@haringey.gov.uk, telephone 020 8489 5504, or see our website at www.haringey.gov.uk/buildingcontrol.