

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

[illegible]

**Borehole
Installation Details**

Borehole Number
514 A

Client & Site Location
Keltbray - wood Green

Well Pipe Material & Type (please circle as appropriate)

Hdpe - Upvc - Direct Push Well - Pre-Packed Wells - Black Mild Steel - Stainless Steel - CMT Multi level

Other Material Please Note:

Single Installation Pipe Diameter : 63 mm OD 50 mm ID

Dual Installation 2nd Pipe Diameter : _____ mm OD _____ mm ID

Cover installed: Chamber / Raised / Flush (Diameter / Size

1m Pipe RAISED / fenced off

~~Concrete~~ From : _____ To _____

Top of Pipe Fitting: Cap Only / Cap & Valve

Bung Only / Valve & Bung

None

Bentonite Seal From : 31.5 m To 0 m

Solid Pipe From : 32 m To 0 m

Geo-wrap Yes / No / N/A

Meters Used : 10 m

Filter Pack From : 42 m To 31.5 m

Filter Pack Details: Gravel / Glass / Sand

Filter Material Size : 3-6 mm

Screen Pipe From : 42 m To 32 m

Base of Monitor Well : 40.5 m

Backfill Material Below Installation:

~~Arisings~~ / Gravel / Bentonite / Sand / Glass

Base of Borehole : 42 m

(this may be the same as the monitor well depth above)

Materials Supplied By

Tick as appropriate

Client ☐

Tor Drilling ☒

General Additional Information

12x Gravel

20x Bento


Water @ 6.2m

Dual Wells Installation Additional
Information

CMT Multi Level Well Installation
Details of Screen Levels:

Upon dipping finished
well, Tape measured
40.5m. Possible sands
settled within pipe.

Please ensure you use a ruler when
drawing any lines to show the
installation details



Date of Installation: 24-2-22

Driller: D. Hewlett

Signature: *D. Hewlett*

