

SIMON HOLLINGWORTH & ASSOCIATES LTD

CHARTERED QUANTITY SURVEYORS PROJECT MANAGEMENT
CONSTRUCTION MANAGEMENT
CONSTRUCTION DESIGN MANAGEMENT CO-ORDINATION

Hadleigh Heath House, Hadleigh Heath, Hadleigh, Ipswich, Suffolk IP7 5NT
Tel: 020 7538 5079 Email: hollprop@simonhollingworth.co.uk

Mr M Gunning
Planning Dept
Haringey Council
108C Gloucester Road
LONDON
N17 6GZ

15 June 2023

Dear Mr Gunning

Re: HGY/2021/1119 - 4 The Chine London N10 3QA

I have been given your name as the Planning Officer dealing with the above and write on behalf of Mr Charles Irvine of the above address.

Condition of the consent requires samples of the external finishes to be submitted. Please therefore take this letter and enclosure as formal submission of details of external finishes.

The proposed brick for the enclosure is a good match to the brickwork on the existing house. The proposed brick is an Imperial size brick. Mortar will be specified to match the existing. The new brickwork will be laid to replicate the coursing of the existing house with snapped headers being used as appropriate. Some photographs of the proposed brick taken against the existing house wall are below.

Enclosed is the Maxlite sample for all of the conservatory roof elements.

Application details are as follows:

Brickwork - Ibstock Swanage Kingston Handmade Light Red Multi Imperial
68mm Ref Code 4356

Glazing - Maxlight aluminium RAL 5002 matt

Should you have any queries, please do not hesitate to contact me.

Simon Hollingworth

Email hollprop@simonhollingworth.co.uk


M: 07970-879718



RICS

The mark of
property professionalism worldwide

Company N° 3931284



**Ibstock Swanage Kingston
Handmade Light Red Multi
Imperial 68mm**

Ref Code: 4356 (Swanage)

Size Tolerance: T1 R1

Brick Dimensions: 228mm x 109mm x 68mm

Compressive Strength: 15 N/mm²

Durability: F2

Maximum Water Absorption: 13%

Active soluble salts: S2

Pack size: 420

British Standard Specials: Available to order

 [Request a sample](#)

 [Ask us a question](#)

Note- 9" coursing will be used and not stretchers only as shown above

Below - Brick sample against existing wall of house

