

Officer's Report

Application Number	HGY/2023/1647
Type	Lawful development: Proposed use
Location	2 Meads Road, Wood Green, London, N22 6RN
Proposal	Certificate of Lawfulness for proposed first floor rear extension
Case Officer	Laina Levassor
Valid Date	21/06/2023
Applicant	Mr B. Ustun
Agent	Mr M Guran

RECOMMENDATION

Refuse

PLANNING HISTORY

The planning history of the site has been taken into account when coming to this decision.

RELEVANT PLANNING LEGISLATION

The application has been made under section 192 of the Town and Country Planning Act 1990 and relevant amendments. This not a planning application but instead the applicant seeks confirmation that the proposed development is lawful. As such, the impact of the proposed development of the neighbour's amenities or the character of the area cannot be taken into consideration for this submission.

ANALYSIS/ASSESSMENT OF THE APPLICATION

Class A: Development within the curtilage of a dwellinghouse

A certificate of lawfulness for a single storey rear extension can be issued if the proposal meets all the criteria under The Town and Country Planning (Generally Permitted Development) (England) Order 2015 – Part 1, Class A 'development within the curtilage of a dwellinghouse'.

The current proposal will be assessed against these requirements as follows:

(a) permission to use the dwellinghouse as a dwellinghouse has not been granted only by virtue of Class M, N, P or Q of Part 3 of this Schedule (changes of use)

Complies

(b) The extension will not exceed more than 50% of the total curtilage of the site.

Complies

(c) The height of the part of the dwellinghouse enlarged, improved or altered would not exceed the height of the highest part of the roof of the existing dwellinghouse.

Complies

(d) The height of the eaves of the part of the dwellinghouse enlarged, improved or altered would not exceed the height of the eaves of the existing dwellinghouse.

Complies

(e) The enlarged part of the dwellinghouse would not extend beyond a wall which—

(i) fronts a highway, and

(ii) forms either the principal elevation or a side elevation of the original dwellinghouse.

Complies

(f) The enlarged part of the dwellinghouse would have a single storey and would not —

(i) extend beyond the rear wall of the original dwellinghouse by more than 4 metres in the case of a detached dwellinghouse, or 3 metres in the case of any other dwellinghouse, or

(ii) exceed 4 metres in height.

N/A - The proposal adjoins an existing ground floor extension therefore is not considered single storey.

(g) until 30th May 2019, for a dwellinghouse not on article 2(3) land nor on a site of special scientific interest, the enlarged part of the dwellinghouse would have a single storey and—

(i) extend beyond the rear wall of the original dwellinghouse by more than 8 metres in the case of a detached dwellinghouse, or 6 metres in the case of any other dwellinghouse, or

(ii) exceed 4 metres in height

N/A - The proposal adjoins an existing ground floor extension therefore is not considered single storey.

(h) The enlarged part of the dwellinghouse would have more than one storey and—

(i) does not extend beyond the rear wall of the original dwellinghouse by more than 3 metres, or

(ii) would not be within 7 metres of any boundary of the curtilage of the dwellinghouse opposite the rear wall of the dwellinghouse.

Fails to comply - the proposed first floor extension would be within 7m of the boundary of the curtilage of 4 Meads Road & 4 Willingdon Road.

(i) The enlarged part of the dwellinghouse would be within 2 metres of the boundary of the curtilage of the dwellinghouse, and the height of the eaves of the enlarged part would not exceed 3 metres;

Complies

(j) The enlarged part of the dwellinghouse would extend beyond a wall forming a side elevation of the original dwellinghouse, and would not—

(i) exceed 4 metres in height,

(ii) have more than one storey, or

(iii) have a width greater than half the width of the original dwellinghouse;

Fails to comply - the first floor extension proposed as part of this application is to be constructed above an existing rear extension which does not benefit from planning permission and would not be considered to meet PD requirements as the extension extends beyond a wall forming a side elevation of the original dwelling house and has a width greater than half the width of the original dwellinghouse.

(k) It would not consist of or include—

(i) the construction or provision of a veranda, balcony or raised platform,

(ii) the installation, alteration or replacement of a microwave antenna,

(iii) the installation, alteration or replacement of a chimney, flue or soil and vent pipe, or

(iv) an alteration to any part of the roof of the dwellinghouse.

Fails to comply - Existing elevations show a s/v pipe located where the proposed extension would be.

Proposed elevations appear to show this would be reinstated with construction of the first floor extension.

A.2. In the case of a dwellinghouse on article 2(3) land, development is not permitted by Class A if—

(a) it would consist of or include the cladding of any part of the exterior of the dwellinghouse with stone, artificial stone, pebble dash, render, timber, plastic or tiles;

(b) the enlarged part of the dwellinghouse would extend beyond a wall forming a side elevation of the original dwellinghouse; or

(c) the enlarged part of the dwellinghouse would have more than one storey and extend beyond the rear wall of the original dwellinghouse.

Complies

Development is permitted by Class A subject to the following conditions:

(a) The materials used in any exterior work (other than materials used in the construction of a conservatory) shall be of a similar appearance to those used in the construction of the exterior of the existing dwellinghouse.

Complies

(b) Any upper-floor window located in a wall or roof slope forming a side elevation of the dwellinghouse shall be—

(i) obscure-glazed, and

(ii) non-opening unless the parts of the window which can be opened are more than 1.7 metres above the floor of the room in which the window is installed;

Fails to comply

(c) Where the enlarged part of the dwellinghouse has more than one storey, the roof pitch of the enlarged part shall, so far as practicable, be the same as the roof pitch of the original dwellinghouse.

Complies

SUMMARY AND CONCLUSION

For the reasons detailed above, the proposal fails to comply with the requirements and limitations of Class A, therefore a certificate cannot be issued.