



FOR APPROVAL

GENERAL NOTES

THIS DRAWING IS THE COPYRIGHT OF DELTA HOUSE GROUP AND SHALL NOT BE COPIED OR REPRODUCED WITHOUT PRIOR EXPRESS PERMISSION.

THIS DRAWING SHOULD NOT BE USED FOR SCALING. ANY SCALED DIMENSIONS ARE TO BE CONFIRMED BY THE CONTRACT ADMINISTRATOR/ARCHITECT.

UNLESS STATED OTHERWISE, ALL DIMENSIONS ARE IN MILLIMETRES.

MATERIALS AND WORKMANSHIP SHALL BE TO THE BEST OF THEIR RESPECTIVE KIND AND CONFORM WITH THE RELEVANT BRITISH STANDARDS, SPECIFICATIONS AND CODES OF PRACTICE.

THIS DRAWING SHALL BE READ IN CONJUNCTION WITH ALL OTHER DRAWINGS AND THE SERVICES SPECIFICATION DOCUMENT(S).

Ventilation Notes

1. This drawing shall be read in conjunction with all other services, Architectural drawings, project specifications and O&M documentation.
2. All ductwork is to be installed in accordance with DW144C/W172.
3. Fire dampers are located in accordance with fire strategy drawing requirements [see architectural plans].
4. All diffusers and grilles are supported by the structure.
5. All supply ductwork, including supply plenum boxes are thermally insulated.
6. HRU/Extract fans are interlocked with the fire alarm system (shut down on fire alarm registered).

A6	04.08.23	Updated to reflect further consultants comments	CS	CS
A5	28.07.23	Updated to reflect consultants comments	CS	CS
A4	17.07.23	Updated to reflect consultants comments	CS	CS
A3	21.06.23	Updated following consultant comments	CS	CS
A2	12 Feb 23	Updated following TFM 01 Sep 22	CS	CS
REV	DATE	DESCRIPTION	Drawn	Auth

Drawing Status:
FOR APPROVAL

 **DELTA HOUSE**
group

10 James Whatman Court, Turkey Mill,
Maidstone, Kent, ME14 5SS
Tel 0845 62 11 295 info@delta-house.co.uk
Fax 0845 62 11 296 www.delta-house.co.uk

Client:	Pexhurst Services Ltd
Architect:	Architecture & Design Services Ltd
Consultant:	Not applicable
Project:	8 Segro Park, Tottenham Fulfillment Centre White Hart Lane, London N17 7RP
Title:	UNIT ELEVATION WEST AND SOUTH

Drawn DLB	Check/Approved CS	Date Aug 23
Contract No. 6348	Scale 1:50 @A1	Revision
Drawing Number SECTIONS	Revision A1	