



MCS 020 Noise Impact assessment for 6 Bryanstone Road

This assessment was done in relation to the neighbour window most likely to be affected by noise from the heat pump.

This is the result of the assessment:

Step	Instruction	Result
1	Sound power	60
2	Directivity Q	4
3	Distance	10
4	dB reduction	-25
5	Solid barrier	0
6	Sound pressure level	35
7	Background noise	40
8	Difference	5
9	Decibel correction	41.2
10	FINAL RESULT	PASS

Ruth Rico Rodriguez
Sales Engineer
Better Planet UK Ltd



Prepared by Ruth Rico Rodriguez, Sales Engineer, Better Planet UK LTD
Phone number: 0333 090 2932
Email: ruth@betterplanet.co.uk