



Officer Report

Application Number:	HGY/2023/2244
Application Type:	Lawful development: Proposed use
Address:	25 Cheshire Road, Wood Green, London, N22 8JJ
Proposal:	Certificate of lawfulness for the proposed erection of a single storey rear extension.
Case Officer:	Sabelle Adjagboni
Valid Date:	18/08/2023
Applicant:	Tim O'Sullivan
Agent:	Mrs Arita Beqiri

RECOMMENDATION

Permitted Development

RELEVANT PLANNING AND ENFORCEMENT HISTORY

The exiting property is a single dwelling house. There is no relevant planning history.

DETAILS OF PROPOSAL

This is an application for a certificate of lawfulness for the erection of a single storey rear extension.

RELEVANT PLANNING LEGISLATION

The application has been made under section 192 of the Town and Country Planning Act 1990 and relevant amendments. This not a planning application but instead the applicant seeks confirmation that the proposed development is lawful. As such, the impact of the proposed development of the neighbour's amenities or the character of the area cannot be taken into consideration for this submission.

ANALYSIS/ASSESSMENT OF THE APPLICATION

Class A: Development within the curtilage of a dwellinghouse

A certificate of lawfulness for a single storey rear extension can be issued if the proposal meets all the criteria under The Town and Country Planning (Generally Permitted Development) (England) Order 2015 – Part 1, Class A 'development within the curtilage of a dwellinghouse'.

The current proposal will be assessed against these requirements as follows:

A.1 Development is not permitted by Class A if -

(a) Permission to use the dwellinghouse as a dwellinghouse has not been granted only by virtue of Class M, N, P, PA or Q of Part 3 of the GPDO (changes of use);

Proposal complies.

(b) As a result of the works, the total area of ground covered by buildings within the curtilage of the dwellinghouse (other than the original dwellinghouse) would exceed 50% of the total area of the curtilage (excluding the ground area of the original dwellinghouse);

Proposal complies.

(c) The height of the part of the dwellinghouse enlarged, improved or altered would exceed the height of the highest part of the roof of the existing dwellinghouse;

Proposal complies.

(d) The height of the eaves of part of the dwellinghouse enlarged, improved or altered would exceed the height of the eaves of the existing dwellinghouse;

Proposal complies.

(e) The enlarged part of the dwellinghouse would extend beyond a wall which-

(i) Forms the principal elevation of the original dwellinghouse; or

(ii) Fronts a highway and forms a side elevation of the original dwellinghouse;

Not applicable

(f) The enlarged part of the dwellinghouse would have a single storey and-

(i) Extend beyond the rear wall of the original dwellinghouse by more than 4 metres in the case of a detached dwellinghouse, or 3 metres in the case of any other dwellinghouse;

(ii) Exceed 4 metres in height;

Proposal complies.

(g) For a dwellinghouse not on article 2(3) land nor on a site of special scientific interest, the enlarged part of the dwellinghouse would have a single storey and-

(i) extend beyond the rear wall of the original dwellinghouse by more than 8 metres in the case of a detached dwellinghouse, or 6 metres in the case of any other dwellinghouse, or

(ii) exceed 4 metres in height;

Proposal complies.

(h) The enlarged part of the dwellinghouse would have more than a single storey and-

(i) extend beyond the rear wall of the original dwellinghouse by more than 3 metres, or;

(ii) be within 7 metres of any boundary of the curtilage of the dwellinghouse being enlarged which is opposite the rear wall of that dwellinghouse;

Not applicable as single storey.

(i) The enlarged part of the dwellinghouse would be within 2 metres of the boundary of the curtilage of the dwellinghouse, and the height of the eaves of the enlarged part would exceed 3 metres;

Proposal complies.

(j) The enlarged part of the dwellinghouse would extend beyond a wall forming a side elevation of the original dwellinghouse, and would-

(i) Exceed 4 metres in height, or

(ii) Have more than a single storey, or

(iii) Have a width greater than half the width of the original dwellinghouse

Proposal complies

(ja) any total enlargement (being the enlarged part together with any existing enlargement of the original dwellinghouse to which it will be joined) exceeds or would exceed the limits set out in subparagraphs (e) to (j);

Proposal complies

(k) It would consist of or include-

- (i) The construction or provision of a verandah, balcony or raised platform,
- (ii) The installation, alteration or replacement of a microwave antenna,
- (iii) The installation, alteration or replacement of a chimney, flue or soil and vent pipe, or
- (iv) An alteration to any part of the dwellinghouse

Above non-applicable

(l) The dwellinghouse is built under Part 20 of this Schedule (construction of new dwellinghouses).
Proposal complies.

A.2 Article 2(3) land

In the case of a dwellinghouse on article 2(3) land, development is not permitted by Class A if—
(The dwellinghouse is not on article 2(3) land and as such the following are not applicable).

- (a) it would consist of or include the cladding of any part of the exterior of the dwellinghouse with stone, artificial stone, pebble dash, render, timber, plastic or tiles;
- (b) the enlarged part of the dwellinghouse would extend beyond a wall forming a side elevation of the original dwellinghouse; or
- (c) the enlarged part of the dwellinghouse would have more than a single storey and extend beyond the rear wall of the original dwellinghouse.

A3. Conditions

Development is permitted by Class A subject to the following conditions-

- (a) the materials used in any exterior work (other than materials used in the construction of a conservatory) must be of a similar appearance to those used in the construction of the exterior of the existing dwellinghouse;

Materials to match

- (b) any upper-floor window located in a wall or roof slope forming a side elevation of the dwellinghouse must be-
 - (i) obscure-glazed, and
 - (ii) non-opening unless the parts of the window which can be opened are more than 1.7m metres above the floor of the room in which the window is installed.

N/A.

- (c) where the enlarged part of the dwellinghouse has more than a single storey, or forms an upper storey on an existing enlargement of the original dwellinghouse, the roof pitch of the enlarged part must, so far as practicable be the same as the roof pitch of the original dwellinghouse.

Proposal complies.

RECOMMENDATION

The proposed development constitutes permitted development by virtue of Schedule 2, Part 1, Class A of the Town and Country Planning (General Permitted Development) Order 2015 and is considered to be lawful.

Informatives:

INFORMATIVE: The applicant is reminded that in order for the proposed extension and alterations to comply with Class A, Part 1, Schedule 2 of the Town and Country Planning (General Permitted Development) Order 2015 (as amended), the materials used in any exterior work must be of a similar appearance to those used in the

construction of the exterior of the existing dwellinghouse.