

Subject: RE: LPS1175SR1 grills
Date: Thursday, 2 March 2023 at 15:40:46 Greenwich Mean Time
From: Lee.J.Warwick@met.police.uk
To: Calvin Scherer, Raphael Arthur
Attachments: image001.png, image002.gif, image003.gif, image008.jpg, image009.jpg

Good afternoon Calvin

I believe that we made this development a gated business community (out of hours) therefore EN 1627 RC2 should be sufficient for the shutter doors with the following caveats

- There is the facility to alarm the premises (fused spur)
- Any windows below 1.8m in height are minimum of P4A Glazing tested to the following method EN 356 : 1999 : 'Glass in building - Security glazing - Testing and classification of resistance against manual attack
- If there is a door way fitted into the sectional overhead door, then the LPS1175SR1 grill will be installed to mitigate the risk.

Hope this assists, please confirm

lee



Lee Warwick
Police Constable | Designing Out Crime Officer
Metropolitan Police Service
Crime Prevention, Inclusion and Engagement (CPIE)
London Safety Centre
p: 0208 217 3813 (753813) m: 07776678490
a: Basement, Bow Road Police Station, 115-117 Bow Road, E3 2AN
w: www.met.police.uk e: lee.j.warwick@met.police.uk
office: DOCOMailbox.NE@met.police.uk



[MPS Crime Prevention Advice](#) | [Internal Advice for Staff](#)



<https://www.pcnicolahughesmemorialfund.co.uk>

The PC Nicola Hughes Memorial Fund was established in 2014 by Bryn Hughes, in memory of his daughter who was killed in 2011, to provide funding for Education & Pre Employment for those under the age of 21 who are left behind after one through murder or manslaughter.

Please contact the charity or me for more information about upcoming events or to make a donation in support of the fund.

NEW YORK 2022 Fundraiser

<https://pcnicolahughes.enthuse.com/pf/leewarwick>

From: Calvin Scherer <calvin@turner.works>
Sent: 02 March 2023 14:39
To: Warwick Lee J - Professionalism Headquarters <Lee.J.Warwick@met.police.uk>; Raphael Arthur <raphael@turner.works>
Subject: Re: LPS1175SR1 grills

Hi Lee,

Just contacting to request some additional advice regarding another type of external door on the Florentia Village project.

We have a number of Sectional Overhead doors (much like this: <https://www.arrow-industrial.co.uk/industrial-doors/sectional-overhead-doors/>). Our choices for these type of doors are limited by requirements to achieve the U values needed to reach the BREEAM Excellent certification that Haringey Council require of this project. However, these Sectional overhead doors achieve the security rating of EN 1627 RC2, would this be an acceptable alternative rating? The contractor has confirmed that availability of these types of doors that meet the thermal performance and the security rating are largely non existent. As an alternative would the EN 1627 RC2 doors with the LPS1175SR1 grilles behind be acceptable?

A response by the end of the day will be much appreciated.

Kind Regards

Calvin Scherer
Architectural Assistant

Turner Works

Block D
Echo Building
Hackney Bridge
London E15 2SJ

T: 020 3846 1890
W: www.turner.works

— — —

Winner, AR Future Project Award 2022
Winner, Civic Trust Pro Tem Award 2022
Winner, NLA Workspace Award 2021
Winner, RIBA London Award 2021
Winner, RIBA South East Award 2021
Shortlisted, BD Individual House Architect of the Year 2021
Shortlisted, BD Social Impact Architect of the Year 2021
Highly Commended, AJ Retrofit Award 2019
Shortlisted, NLA Education Award 2019
Shortlisted, BD Public Building Architect of the Year 2018
Winner, NLA Meanwhile Award 2018
BD Small Project Architect of the Year 2017
Winner, Manser Medal 2013

Winner, RIBA National Award 2013

From: Lee.J.Warwick@met.police.uk <Lee.J.Warwick@met.police.uk>

Date: Tuesday, 28 February 2023 at 17:06

To: Calvin Scherer <calvin@turner.works>

Subject: LPS1175SR1 grills

Hi Calvin

Here is the LPS1175SR1 rated grills to behind the PAS24 doorset. If you do a search for a similar description you will find other suppliers

Lee

<https://bradbury-group.com/news/product-guide-grilles-cages-bar-sets/>



Lee Warwick
Police Constable | Designing Out Crime Officer
Metropolitan Police Service
Crime Prevention, Inclusion and Engagement (CPIE)
London Safety Centre
p: 0208 217 3813 (753813) m: 07776678490
a: Basement, Bow Road Police Station, 115-117 Bow Road, E3 2AN
w: www.met.police.uk e: lee.j.warwick@met.police.uk
office: DOCOMailbox.NE@met.police.uk



[MPS Crime Prevention Advice](#) | [Internal Advice for Staff](#)



<https://www.pcnicolahughesmemorialfund.co.uk>

The PC Nicola Hughes Memorial Fund was established in 2014 by Bryn Hughes, in memory of his daughter who was killed in 2013, to provide funding for Education & Pre Employment for those under the age of 21 who are left behind after one through murder or manslaughter.

Please contact the charity or me for more information about upcoming events or to make a donation in support of the fund.

NEW YORK 2022 Fundraiser

<https://pcnicolahughes.enthuse.com/pf/leewarwick>

NOTICE - This email and any attachments are solely for the intended recipient and may be confidential. If you have received this email in error, please notify the sender and delete it from your system. Do not use, copy or disclose the information contained in this email or in any attachment without the permission of the sender. Metropolitan Police Service (MPS) communication systems are monitored to the extent permitted by law and any email and/or attachments may be read by monitoring staff. Only specified personnel are authorised to conclude binding agreements on behalf of the MPS by email and no responsibility is accepted for unauthorised agreements reached with other personnel. While reasonable precautions have been taken to ensure no viruses are present in this email, its security and that of any attachments cannot be guaranteed.

NOTICE - This email and any attachments are solely for the intended recipient and may be confidential. If you have received this email in error, please notify the sender and delete it from your system. Do not use, copy or disclose the information contained in this email or in any attachment without the permission of the sender. Metropolitan Police Service (MPS) communication systems are monitored to the extent permitted by law and any email and/or attachments may be read by monitoring staff. Only specified personnel are authorised to conclude binding agreements on behalf of the MPS by email and no responsibility is accepted for unauthorised agreements reached with other personnel. While reasonable precautions have been taken to ensure no viruses are present in this email, its security and that of any attachments cannot be guaranteed.