

from Ordnance Survey with the permission of HMSO © Crown Copyright LBH 2011. All rights reserved.
License number 100019199.

NOTES:

- Luminaire A Column
 - Luminaire B Column
 - Luminaire C Column
 - Beam Aiming Target
 - Photometric Centre
 - FP Feeder Pillar
- SWA Cable

Pull Chambers

SWA Cakile

SWAL Cable should be to
SS6387/SWAL/LSZH Cable IEC6050
600/1000V 3 core 6mm²
VVC/SWALSZH Single wired
unarmoured cable with the outer sheath
coloured black and marked 'street
lighting cable' at intervals not
exceeding 0,25m and the internal
cores coloured brown, blue, green &
yellow.

Columns

Urbis Lighting 6mt column complete with post Top mounted Urbis Axa 2.1 31.5w 3000K lantern complete with Movement sensor & MDS node.

[illegible]

Street Lighting LAYOUT PLAN

Designed:	Drawn:	Checked:
MA	MA	KW
Date:		Date Drawing Created:
NTS		June 2025

ENVIRONMENT & RESIDENT EXPERIENCE

HIGHWAYS & TRAFFIC

401 Brook, Marlborough House, 10 St
Wood Green, London N22 7
Tel: 020 8469 0000

Discrete Mark Servers

