

## **Pressure test Certification**

### **Tottenham**

**Location – Third floor Right side of building**

**Tested with Air**

Pressure test carried out for one hour at 4 bar Flow & Return



Test - **Passed**



Test carried out by – Harry Martin

Date – 20/02/2025