



Pressure test Certification

Tottenham

Location – Third floor Right side of building

Tested with Air

Pressure test carried out for one hour at 4 bar Flow & Return



Test - **Passed**

Test carried out by – Harry Martin

Date – 20/02/2025