

ELECTRICAL SERVICES SYMBOL LEGEND:

- LINETYPES:**
- | | |
|---------|------------------------------------|
| ———— | CIRCUIT LINE (SWITCHED TOGETHER) |
| — — — — | CIRCUIT LINE (SWITCHED SEPERATELY) |

CU	CONSUMER UNIT
DB	DOOR BELL
DW	DISHWASHER
EH	EXTRACT COOKER HOOD
FF	FRIDGE FREEZER
G	4 PLATE GRID SWITCH
H/L	HIGH LEVEL
HOB	HOB COOKER
L/L	LOW LEVEL
M/L	MID LEVEL
WP	WEATHER PROOF
WM	WASHING MACHINE
S	SHAVER SOCKET
TR	TOWEL RAIL (ELECTRIC)
UFHM	UNDERFLOOR HEATING MANIFOLD

0 1m 2m 3m 4m 5m

0mm 100mm

SCALE 1:50



12-WAY DUAL RCD SP&N CONSUMER UNIT

- | MODEL LINKS | | |
|-------------|---------------------|------|
| Type: | File Name: | Rev. |
| DWG | 240129_6940_BLOCK_D | ... |

- * DRAWING TO BE READ IN CONJUNCTION WITH CLIENTS ER's & CONTRACT DOCUMENTS
- * SELLING OUT TO BE CO-ORDINATED ON SITE WITH STUD POSITIONS
- * WHERE OUTLETS ARE ADJACENT ALLOW FOR A 40mm GAP BETWEEN
- * ALL EQUIPMENT TO BE INSTALLED IN LINE WITH MANUFACTURERS RECOMMENDATIONS
- * DRAWING TO BE READ IN CONJUNCTION WITH LUMINAIRE SCHEDULE

- * DRAWING TO BE READ IN CONJUNCTION WITH CLIENTS ER'S & CONTRACT DOCUMENTS
- * INSTALLATION TO BE CO-ORDINATED WITH MECHANICAL DRAWINGS
- * SETTING OUT TO BE CO-ORDINATED ON SITE WITH STUD POSITION
- * WHERE OUTLETS ARE ADJACENT ALLOW FOR A 40mm gap BETWEEN
- * ALL EQUIPMENT TO BE INSTALLED IN LINE WITH MANUFACTURERS RECOMMENDATIONS
- * SETTING OUT IN LINE WITH ARCHITECT FURNITURE LAYOUTS
- * NO BACK TO BACK SOCKETS OR ACCESSORIES
- * THE CONTRACTOR SHALL NOTE THE FOLLOWING:
 - DISTRIBUTION BOARD - 1350mm AFFL TO SWITCHES
 - SOCKETS & SWITCHES - 450-1200mm AFFL
 - SOCKET OUTLETS TO BE AT LEAST 300mm AWAY FROM ANY INTERNAL CORNER
 - ALL TV POINTS, THEATRE STAIRS ETC. TO ALSO BE IN COMPLIANCE WITH PART M
- * WITHIN KITCHENS, ALL ELECTRICAL ACCESSORIES ABOVE WORKTOP LEVEL ARE TO BE INSTALLED 300mm(MINIMUM) CLEAR FROM SINK/DRAINER & 150mm (MINIMUM) CLEAR OF HOB

P01	06.02.25	APPROVAL ISSUE	CD	DS	CD
Rev.	Date:	Description:	Eng:	Drn:	Apr:



Project:

BRUNEL WALK

TYPE S DUPLEX UNIT 40 ELECTRICAL LAYOUT

Scale:	Date:	Checked:	Suitability:
--------	-------	----------	--------------

Drawing Status:	Revision:
-----------------	-----------

STAGE 4 - APPROVAL

0053-KCL-00-ZZ-D-E-2231