EML
M25

emlite
1 Slevern Way, Peterborough PE1 5EL

EML
M25

Model Number:
ECA2.nz
V1
1000 Imp/ kWh Cl.B
230V 50Hz 1,0-20(100)A
-40°C...+70°C
2025

EXP
IMP
NET
kWh

EML2548714358

UK CA M25 0120 CE M25 0598 0120
SGS0103

PHOTOVOLTAIC SYSTEM

Place on AC iso

IP65 4P32A

Clearline
INVERTER
INVERTER
WARNING - Dual Supply
Isolate AC and DC
before carrying out work
Place on inverter front cover
viridian
solar
PV Array DC Isolator
WARNING
Contains live parts during daylight
DO NOT
disconnect DC plugs
and sockets under load
- turn off AC supply first
LOCK
EML2548714358
PHOTOVOLTAIC
SYSTEM
Solar PV System
Point of Emergency
switching
IP65 4P32A

Clearline
INVERTER

ct: Grid-Tied PV Inverter
: CSI2000S

Input	U_{DCmax}: 600Vd.c.
	U_{MPP}: 40...450Vd.c.
	$I_{DC,max}$: 16Ad.c.
	$I_{SC\ PV}$: 25Ad.c.
Output	$U_{AC,r}$: 220/230/240Va.c.
	$f_{AC,r}$: 50/60Hz
	$P_{AC,r}$: 2000W
	$I_{AC,max}$: 9.1Aa.c.
	S_r: 2000VA
	S_{max}: 2000VA

.: ~1,0.8cap...0.8ind, $T_{operating}$: -25...+60°C
-isolated, IP66, Protective Class I, OVC DCII/ACIII

5min

CE

N: 22000SSA24BR0006

Code: 046001

WARNING
ISOLATE ELSEWHERE BEFORE REMOVING THIS COVER
Solar PV on roof
WARNING
Dual Supply
Do not work on this equipment until it is isolated from both the mains and the on-site generation supplies
Isolate on-site generator at:
Isolate the mains supply at:
hager
MAINS SMOKE / HEAT ALARMS
HOW TO REMOVE ALARM
SWITCH OFF THE MAINS SUPPLY. RELEASE CATCH ON ALARM BY PUSHING SCREWDRIVER INTO SLOT & PUSH COVER AWAY
SLOT
PUSH COVER
DATE INSTALLED:
NO. OF ALARMS ON CIRCUIT:
WARNING: DO NOT BREAKER ALARMS