

Outcome of Construction Site Emissions Audit

21 May 2026

Storex Tottenham
30-48 Lawrence Road



Principal Contractor at site: Morda Construction
Representative: Morgan Fouracre

Auditor: Elizabeth Gunner

nrmm@merton.gov.uk

www.merton.gov.uk/nrmm



SUPPORTED BY
MAYOR OF LONDON

Requirements to pass the audit:

To be enacted within 5 working days from receipt of this report.
Thereafter, you are expected to continue to keep your site's NRMM registration updated.

1

2

Current Compliance Status
Self-Compliant Excellent

Additional Recognition	
Machinery beyond compliance	✓
Full historic record of machinery	✓
Off-scope emissions reductions	✓
Evidenced plate checks	

Comments (if any):

Emission Code	Emission Stage	Power Band (kW)
A	EU Stage I	130 - 560
B		75 - 130
C		37 - 75
D*	EU Stage II	18 - 37
E		130 - 560
F		75 - 130
G		37 - 75
H	EU Stage IIIA	130 - 560
I		75 - 130
J		37 - 75
K*		19 - 37
L	EU Stage IIIB	130 - 560
M		75 - 130
N		56 - 75
P		37 - 56
Compliance boundary		
Q	EU Stage IV	130 - 560
R		56 - 130
EV1 or EC1*	EU Stage V	0 - 8
EV2 or EC2*		8 - 19
EV3 or EC3*		19 - 37
EV4 or EC4		37 - 56
EV5 or EC5		56 - 130
EV6 or EC6		130 - 560
EV7 or EC7*		>560

*Note: machines in categories below 37kW or above 560kW are currently exempt.