

Steve Eldergill


From: Adam Rothwell
Sent: Tuesday 16 June 2026 15:05
To: Samuel Uff; Elisabetta Tonazzi; Chris Hill
Cc: Eduarda Vieira; Steve Eldergill; Niall Tallis1; John McRory; Jade Pleass; Harry Nahum; Harringey Dalux Archive; Liz Pickard; Gwyn Williams
Subject: Civic Centre On-Site Recurring Meeting - 11th June meeting minutes
Attachments: Haringey Civic Centre - Draft Lobby Canopy Survey.pdf; HCC-CTF-ZZ-00-DR-L-100000.pdf; 556-CTF-XX-XX-PR-L-0008_Paving presentation_CTF proposal.pdf

All,

Following the meeting last week please see below the minutes:

External lobby doors to civic centre

1. SISK presented to LBO that attaching the existing green marble push bars wouldn't be possible. Attaching any non-tested ironmongery on to PAS 24 certified door will invalidate the certification.



2. It was agreed that the marble inlay would be fixed/reused only to the internal set of doors in the lobby doors (not PAS 24) and not the external set. The window and door subcontractor is in the process of confirming that this is possible with the additional weight on the selected hinges.

Soffit to civic centre main canopy

3. Artisan's surveys indicate the suspended ceiling requires replacement and SISK are proposing this be fully replaced as per the subcontractor report. See attached.
4. The proposal would be to match the same finish and replace the existing lights with new with the required IP rating for external lighting.

Paint to 3rd Floor to Match GRC

5. Sandstone is the best match see below.

Paint to civic window surrounds

6. Use sandstone as well to match GRC
7. Mastic too dark – Sisk will provide lighter sample for approval
8. Sisk have confirmed one window bay will be completed and offered for approval.

Glazed screen cleaning sample

9. IG concluded a sample to aluminium screens cleaning and the sample looks in good condition. As expected, some existing scratches or deeper marks or use will not be able to be sanded, however we believe this could be acceptable and expected.
10. Any post fixed locks that are not part of the original design are to be removed.
11. Glass that has been damaged will be replaced with new. It was acknowledged that new glass will be differentiated, SISK will provide sample of new glass to put next to existing and see colour.
12. Glass film solutions and methodology need to be provided by IG .
13. MEP solution on access control – vertical metal pole.

Floor to stair lobby

14. From a conservation perspective, if a perfect match cannot be achieved, a more solid colour is preferred. It is important that the infill does not overpower the existing terrazzo and, most importantly, maintains the same base colour as the existing terrazzo to ensure a consistent appearance.



Landscape

15. Conservation Officer need a more detail design of the proposal along side samples to be demonstrated by CTF, namely around the front of the building which is more sensitive.

16. Required by LBO

- a. detail landscape proposals (See attached)
- b. sample board and or + CGI

17. Sisk to follow up actions with CTF

Landscape

18. Conservation officer was in broad agreement with the green tone for the Council chamber, however subject to confirmation on site next to the timber
19. However, the following colours were rejected :
Red/terracotta was not accepted for the committee rooms because it overtakes the timber. The key concern was that the colour selection did not tie in with the historical palette of the existing building and would be too overpowering.
Options preferred: mushroom, blue, green.
20. Dark carpet for circulation on the grounds that it is too dark.

Regards

Adam

Adam Rothwell
Senior Design Manager
MA ARB CIOB

Contact

T +447442887725
M +447442887725
sisk.com

Sisk

Haringey Civic Centre
255 High Road
Wood Green
N22 9SB



INVESTORS IN PEOPLE®
We invest in people Platinum

**BUILDING A FUTURE
WHERE EVERYONE BELONGS**

We value our people and are actively working to improve Work/Life Balance. As such, whilst it suits me to send this e-mail now, I do not anticipate a response or action if it is outside of your normal working hours.

-----Original Appointment-----

From: Samuel Uff <Samuel.Uff@haringey.gov.uk>

Sent: Thursday 2 April 2026 14:59

To: Samuel Uff; Elisabetta Tonazzi; Chris Hill; Adam Rothwell

Cc: Eduarda Vieira; Steve Eldergill; Niall Tallis1; John McRory

Subject: Civic Centre On-Site Recurring Meeting

When: Thursday 11 June 2026 14:30-16:30 (UTC+00:00) Dublin, Edinburgh, Lisbon, London.

Where: Microsoft Teams Meeting

CAUTION: This email originated from outside the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Hopefully this recurring meeting will stick! Forward on to anyone else who may wish to attend.

Microsoft Teams meeting

Join:

<https://teams.microsoft.com/meet/334647831977072?p=Xq3FLyq8AzkoKg5wu>
[u](#)

Meeting ID: 334 647 831 977 072

Passcode: ag6ht6sA

[Need help?](#) | [System reference](#)

This email and any files transmitted with it are confidential, may be subject to legal privilege and are intended only for the person(s) or organisation(s) to whom this email is addressed. Any unauthorised use, retention, distribution, copying or disclosure is strictly prohibited. If you have received this email in error, please notify the system administrator at Haringey Council immediately and delete this e-mail from your system. Although this e-mail and any attachments are believed to be free of any virus or other defect which might affect any computer or system into which they are received and opened, it is the responsibility of the recipient to ensure they are virus free and no responsibility is accepted for any loss or damage from receipt or use thereof. All communications sent to or from external third party organisations may be subject to recording and/or monitoring in accordance with relevant legislation.