From: DAA Group <enquiries@daagroup.co.uk>
Sent: 13 May 2025 11:22
To: Josh Parker (Haringey)
Subject: Re: HGY/2024/2452 - 47, Grovelands Road, Haringey, London N15 6BT

Document on the Haringey register for HGY/2024/2452 titled "clarification on the glazing" (20/5/2025), listed on the decision notice. Converted from the council's .msg file; the NIA it attaches is the approved Noise Impact Assessment in this folder.

Hi Josh

The report states on Page 17:

"calculations indicate that target noise levels can be met using acoustically specified acoustic double glazing options with an acoustic performance in the order of Rw 43 dB for all areas. Due to the character of live voices and music, the performance of the glazing at 250Hz will be no less than Rw34 dB. This can typically be achieved by glazing systems such as Guardian Glass 6mm / 16mm / 11.4mm Lamiglass , or equivalent. See Appendix B. "

Kind Regards

Laura Jennings

Kind Regards

DAA Group Team

DAAGroup Ltd

Tel: 020 7 101 9669

www.passmysoundtest.co.uk <http://www.passmysoundtest.co.uk>

www.passmysoundtest.co.uk <http://www.passmysoundtest.co.uk/>
----------SERVICES----------

* Sound Insulation Testing (Part E)
* Air Tightness Testing (Part L)
* Ventilation Testing (Part F)
* Water Calculations (Part G)
* SAP & EPCs
* Noise Assessment Surveys BS4142 & BS8233

----------SERVICES----------

Company Confidential (Unless otherwise stated).
This e-mail is for the use of the intended recipient(s) only. If you have received this e-mail in error, please notify the sender immediately and then delete it. If you are not the intended recipient, you must not use, disclose or distribute this e-mail without the author's prior permission. We have taken precautions to minimise the risk of transmitting software viruses, but we advise you to carry out your own virus checks on any attachment to this message. We cannot accept liability for any loss or

damage caused by software viruses. If you are the intended recipient and you do not wish to receive similar electronic messages from us in the future then please respond to the sender to this effect.

Copyright:

Terms & Conditions

* We do not release any reports or documentation relating to services carried out by DAA GROUP prior to full payment of the issued invoice(s).
* Any cancellation not notified in writing (Email) within 48hrs of any service that requires site attendance, will be subjected to pay 50% of the final invoice.
* Failure to notify DAA of a cancelation and leading to a DAA employee to attend site, will be classed as a "no show" and will be subjected to the full amount of the final invoice.
* Any specification or guidance sent by email will be classed as design input and charged at an hourly rate, with a minimum charge of 1 hour @ £65 per hour.
* Any sound insulation test not paid within 30days of the testing date, will be subject to full payment without certification being issued due to possible data corruption.

From: Josh Parker <Josh.Parker@haringey.gov.uk>
Sent: Tuesday, May 13, 2025 12:11 PM
To: DAA Group <enquiries@daagroup.co.uk>
Subject: RE: HGY/2024/2452 - 47, Grovelands Road, Haringey, London N15 6BT

Hi Laura,

Just need confirmation that the glazed openings would meet the condition.

I’m not sure if the report specifically mentions this? I don’t think I recall this being mentioned.

Kind regards,

Josh Parker

Planning Officer – Development Management

Environment & Resident Experience

Alexander House, 10 Station road, Wood Green, London N22 7TR

www.haringey.gov.uk <http://www.haringey.gov.uk/>

Please note the above opinion represents informal officer observation only, offered without prejudice to all future formal Council decisions and accompanying procedures

From: DAA Group <enquiries@daagroup.co.uk>
Sent: 13 May 2025 11:46
To: Josh Parker <Josh.Parker@haringey.gov.uk>
Subject: HGY/2024/2452 - 47, Grovelands Road, Haringey, London N15 6BT

Hi Josh

Please can you elaborate on what further information you require regarding the noise impact assessment.

Kind Regards

Laura Jennings

DAAGroup Ltd

Tel: 020 7 101 9669

www.passmysoundtest.co.uk <http://www.passmysoundtest.co.uk>

www.passmysoundtest.co.uk <http://www.passmysoundtest.co.uk/>

----------SERVICES----------

* Sound Insulation Testing (Part E)
* Air Tightness Testing (Part L)
* Ventilation Testing (Part F)
* Water Calculations (Part G)

* SAP & EPCs
* Noise Assessment Surveys BS4142 & BS8233

----------SERVICES----------

Company Confidential (Unless otherwise stated).

This e-mail is for the use of the intended recipient(s) only. If you have received this e-mail in error, please notify the sender immediately and then delete it. If you are not the intended recipient, you must not use, disclose or distribute this e-mail without the author's prior permission. We have taken precautions to minimise the risk of transmitting software viruses, but we advise you to carry out your own virus checks on any attachment to this message. We cannot accept liability for any loss or damage caused by software viruses. If you are the intended recipient and you do not wish to receive similar electronic messages from us in the future then please respond to the sender to this effect.

Copyright:

Terms & Conditions

* We do not release any reports or documentation relating to services carried out by DAA GROUP prior to full payment of the issued invoice(s).
* Any cancellation not notified in writing (Email) within 48hrs of any service that requires site attendance, will be subjected to pay 50% of the final invoice.
* Failure to notify DAA of a cancelation and leading to a DAA employee to attend site, will be classed as a

"no show" and will be subjected to the full amount of the final invoice.

* Any specification or guidance sent by email will be classed as design input and charged at an hourly rate, with a minimum charge of 1 hour @ £65 per hour.
* Any sound insulation test not paid within 30days of the testing date, will be subject to full payment without certification being issued due to possible data corruption.

This email and any files transmitted with it are confidential, may be subject to legal privilege and are intended only for the person(s) or organisation(s) to whom this email is addressed. Any unauthorised use, retention, distribution, copying or disclosure is strictly prohibited. If you have received this email in error, please notify the system administrator at Haringey Council immediately and delete this e-mail from your system. Although this e-mail and any attachments are believed to be free of any virus or other defect which might affect any computer or system into which they are received and opened, it is the responsibility of the recipient to ensure they are virus free and no responsibility is accepted for any loss or damage from receipt or use thereof. All communications sent to or from external third party organisations may be subject to recording and/or monitoring in accordance with relevant legislation.