Block Compliance

Block Reference	BK093 - Tiverton A Green	**Issued on Date**	12/11/2026
Block Name	Tiverton		
Calculation Type	New Build (As Designed)	**SAP Version**	10.2
Assessor Details	Mr. Matthew Carter	**Assessor ID**	7869-0001
Client	Alexander James Contracts Limited , Alexander James Contracts Limited , Suite D, Tower House , Little Chalfont , HP5 1TU		

Block Compliance Report - DER

Block Reference: BK093 - Tiverton A Green	Block Name: Tiverton			
Property-Assessment Reference	**Floor area (m^2)**	**DER ($kgCO_2/m^2$)**	**TER ($kgCO_2/m^2$)**	**% DER/TER**
02089- A1 - 00001	120.04	3.42	12.70	73.07 %
02090- A2 - 00001	90.80	3.52	15.22	76.87 %
02091- A3 - 00001	58.00	2.94	14.67	79.96 %
02092- A4 - 00001	71.36	2.36	11.82	80.03 %
02093- A5 - 00001	72.80	2.84	12.70	77.64 %
02094- A6 - 00001	58.00	2.29	12.36	81.47 %
02095- A7 - 00001	71.36	2.36	11.82	80.03 %
02096- A8 - 00001	72.80	3.40	15.37	77.88 %
02097- A9 - 00001	58.00	2.78	15.03	81.50 %
02098- A10 - 00001	71.36	2.98	15.44	80.70 %
Totals:	744.52	28.89	137.13	
Average DER = 2.95 $kgCO_2/m^2$	**% DER/TER**	PASS		
Average TER = 13.67 $kgCO_2/m^2$	78.40 %			

Block Compliance Report - DFEE

Block Reference: BK093 - Tiverton A Green	Block Name: Tiverton			
Property-Assessment Reference	**Floor area (m^2)**	**DFEE ($kWh/m^2/yr$)**	**TFEE ($kWh/m^2/yr$)**	**% DFEE/TFEE**
02089- A1 - 00001	120.04	47.45	43.81	-8.29 %
02090- A2 - 00001	90.80	47.45	49.04	3.24 %
02091- A3 - 00001	58.00	37.06	37.27	0.56 %
02092- A4 - 00001	71.36	26.33	28.06	6.16 %
02093- A5 - 00001	72.80	35.42	33.06	-7.13 %
02094- A6 - 00001	58.00	26.07	26.83	2.84 %

Block Compliance

02095- A7 - 00001	71.36	26.33	28.06	6.16 %
02096- A8 - 00001	72.80	43.59	45.20	3.58 %
02097- A9 - 00001	58.00	34.45	38.97	11.61 %
02098- A10 - 00001	71.36	37.69	44.63	15.54 %
Totals:	744.52	361.85	374.95	
Average DFEE = 37.43 kWh/m²/yr	**% DFEE/TFEE**	PASS		
Average TFEE = 38.39 kWh/m²/yr	2.50 %			

Block Compliance Report - DPER

Block Reference: BK093 - Tiverton A Green	**Block Name: Tiverton**			
Property-Assessment Reference	**Floor area (m^2)**	**DPER ($kWh/m^2/yr$)**	**TPER ($kWh/m^2/yr$)**	**% DPER/TPER**
02089- A1 - 00001	120.04	37.96	67.01	43.35 %
02090- A2 - 00001	90.80	40.02	80.68	50.40 %
02091- A3 - 00001	58.00	36.75	77.98	52.87 %
02092- A4 - 00001	71.36	29.56	62.50	52.70 %
02093- A5 - 00001	72.80	34.21	67.22	49.11 %
02094- A6 - 00001	58.00	30.27	65.58	53.84 %
02095- A7 - 00001	71.36	29.56	62.50	52.70 %
02096- A8 - 00001	72.80	39.83	81.60	51.19 %
02097- A9 - 00001	58.00	35.16	79.95	56.02 %
02098- A10 - 00001	71.36	35.75	82.01	56.41 %
Totals:	744.52	349.07	727.03	
Average DPER = 35.29 kWh/m²/yr	**% DPER/TPER**	PASS		
Average TPER = 72.45 kWh/m²/yr	51.28 %			