


9 BRUCE GROVE (Ref: HGY/2022/2676 & HGY/2022/2675)			
COND. NUMBER	SUMMARY	CONDITION WORDING	RESPONSE
3 (condition replicated under same number in LBC)	Proposed Materials to Paving and Boundary	All proposed materials and finishes to paving and boundary treatment are to be approved by the Local Planning Authority either on site or through submission of on-site photos of the proposed materials.	Surfacing: Resin-bonded gravel surfacing to be KBI Flexistone; colour 'Barnsley Solo' – see image below 

			New fence details (to top of brick wall): • Steel fence with flat pyramid tops to balusters  Brick wall • As existing
--	--	--	---

			Reconstituted stone coping to boundary wall See image  
--	--	--	--

			Ground level lighting to planting bed - See image EXL.1 Collingwood GL019 Ultra-low Glare  1W mini LED ground light, 350mA/700mA input - Ref. GL019DMBL27 - Dims: 40mm dia, 150mm deep (with tube) 2700K 30° beam angle 60 lumens 60 lumen/watt 25 lux @ 1m 70,000hr lifespan 7 year warranty - IP68, IK07 - Stainless steel - Class 3 1m fly-lead from factory (6mm OD)
--	--	--	---

			Concrete edging to Planter beds / resin bound gravel Travis Perkins Concrete Flat Top Path Edging EF 50mm x 200mm x 915mm   Indicates concrete edging only; all other materials as listed above
--	--	--	---

4	No excavation in Bin Area	Compliance condition: No excavation are permitted with the installation of a new bin area.	We confirm that there will be no excavation to the new bin area – the enclosure is to be fixed to the new surfacing
---	---------------------------	--	---