



Existing guardings on West side of front terrace



Existing guardings on rear terrace

Note: these guardings are even more non compliant than the others with no infil, voids larger than 100mm and are climbable



Existing guardings on South side (front) terrace

Note: Parapet that can be used as a step, compromising the effective height.