



- NOTES:
1. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS STATED OTHERWISE; DO NOT SCALE FROM THIS DRAWING.
  2. TO BE READ IN CONJUNCTION WITH DESIGN DRAWINGS AND NLY BUILDING SERVICES LTD. SPECIFICATION.
  3. ROAD AND CAR PARKING AREAS SHALL MAINTAIN AN AVERAGE LIGHTING LEVEL OF 20 lux
  4. PEDESTRIAN ONLY AREAS SHALL MAINTAIN AN AVERAGE LIGHTING LEVEL OF 5 lux
  5. COLUMN LIGHTS MARKED 'M' ARE REQUIRED TO KEEP AN AVERAGE LIGHTING LEVEL OF 20 lux ON THE ROAD AREAS. THEY DO NOT FORM PART OF THESE WORKS AS THEY FALL OUTSIDE OF THE SITE BOUNDARY BUT SHALL BE INSTALLED AT A LATER DATE BY OTHERS

LEGEND:

L LED STREET LAMP WITH PHOTOCELL AS THORLUX STARFLOOD 20w STF17569LPC OR EQUIVALENT COMPLETE WITH THORLUX COLUMN 4m HIGH.

M = SAME AS L BUT ARE NOT PART OF THESE WORKS

S SURFACE MOUNTED WALL LIGHT AS THORLUX COBALT LED 15W - 4000K COMPLETE WITH SATIN HOOD

**NLY** Building Services Ltd  
Email: info@nlybuildingservices.com Website: www.nlybuildingservices.com

CLIENT: FORMATION  
DESIGN AND BUILD

PROJECT: THE  
CHOCOLATE FACTORY  
BLOCK E2

DRAWING TITLE:  
EXTERNAL  
STREET LIGHTING  
LAYOUT

DRAWING NO: P22009-E-141 REV: C3 PROJECT REV: P22009

SCALE AT A3: 1:100 STATUS: CONSTRUCTION

DATE: 18/10/2023 DRAWN BY: CM CHECKED BY: NY

COPYRIGHT NLY BUILDING SERVICES LTD. OWN THE COPYRIGHT IN THIS DRAWING. THESE WRITTEN CONDITIONS MUST BE FORWARDED BEFORE THIS DRAWING IS USED FOR ANY PURPOSE OTHER THAN THE ONE FOR WHICH IT WAS SUPPLIED.