

Mr Dominic ORiordan
82 Rowditch Lane
London
United Kingdom
SW11 5BX

15 January 2024

**TOWN AND COUNTRY PLANNING ACT 1990
TOWN AND COUNTRY PLANNING (DEVELOPMENT MANAGEMENT PROCEDURE)
(ENGLAND) ORDER 2015
NOTICE OF PLANNING PERMISSION**

Case Reference	HGY/2023/1528
Location	7 Wood Vale, Hornsey, London, N10 3DJ
Proposal	Erection of a single rear extension, formation of rear terrace, external air source heat pump and rainwater storage tank, the construction of a hip to gable extension with installation of solar panels and rooflights to front roof slope, construction of a rear dormer extension with solar panels to the flat roof, replacement of an existing front porch, replacement of front elevation windows, replacement of rear elevation windows, replacement of side elevation window, installation of external wall insulation and the installation of electric vehicle charging point to driveway
Received	12 June 2023

In pursuance of their powers under the above Act, the London Borough of Haringey as Local Planning Authority hereby PERMIT the above development received on the above date.

Title	Description	Date
2206-L(-3)01.pdf	Section - Existing	12 June 2023
2206-L(-2)02.pdf	Roof Plan - Existing	12 June 2023
2206-L(-1)22.pdf	The location plan	12 June 2023
2206-L(-4)21.pdf	Additional plans	12 June 2023
2206-L(-1)02A.pdf	The location plan	12 June 2023
2206-L(-1)01.pdf	Site/Block Plan - Existing	12 June 2023
2206-L(-1)21.pdf	Block plan of the site	12 June 2023
2206-L(-2)21.pdf	Additional plans	12 June 2023
2206-L(-2)01.pdf	Additional plans	12 June 2023
2206-L(-4)01.pdf	Additional plans	12 June 2023

Robbie McNaugher

Robbie McNaugher
Head of Development Management and Planning Enforcement
Planning Service

Conditions: (5)

- 1** The development to which this permission relates must be begun no later than three years from the date of this decision notice, failing which the permission shall be of no effect.

Reason: This condition is imposed by virtue of Section 91 of the Town and Country Planning Act 1990 and to prevent the accumulation of unimplemented planning permissions.

- 2** The development hereby permitted shall be carried out in complete accordance with the approved plans and drawings listed in this decision notice, other than where those details are altered pursuant to the conditions of this planning permission.

Reason: For the avoidance of doubt and in the interests of proper planning.

- 3** The external materials to be used for the proposed development shall match in colour, size, shape and texture those of the existing building.

Reason: In order to ensure a satisfactory appearance for the proposed development, to safeguard the visual amenity of neighbouring properties and the appearance of the locality consistent with Policy D3 of the London Plan 2021, Policy SP11 of the Haringey Local Plan 2017 and Policy DM1 of The Development Management DPD 2017.

- 4** The air source heat pump shall be enclosed by screening before being brought into use and retained thereafter. The noise level from the operation of the air source heat pump hereby approved must not exceed 42dB LAeq (5 min) at 1 metre from the window of a habitable room on the façade of any neighbouring residential property. If, in the opinion of the Local Planning Authority the proposed air source heat pump result in any noise nuisance to the occupant of any neighbouring dwelling the Applicant shall install noise mitigation measures in agreement with the Planning Authority.

Reason: In order to protect the amenities of nearby residential occupiers consistent with Policy D14 of the London Plan 2021 and Policies DM1 and DM23 of The Development Management DPD 2017.

- 5** The air source heat pump shall be enclosed by screening before being brought into use and retained thereafter. The noise level from the operation of the air source heat pump hereby approved must not exceed 42dB LAeq (5 min) at 1 metre from the window of a habitable room on the façade of any neighbouring residential property. If, in the opinion of the Local Planning

Authority the proposed air source heat pump result in any noise nuisance to the occupant of any neighbouring dwelling the Applicant shall install noise mitigation measures in agreement with the Planning Authority.

Reason: In order to protect the amenities of nearby residential occupiers consistent with Policy D14 of the London Plan 2021 and Policies DM1 and DM23 of The Development Management DPD 2017.

Informatives:

INFORMATIVE: Land Ownership

The applicant is advised that this planning permission does not convey the right to enter onto or build on land not within his ownership.

INFORMATIVE: Party Wall Act

The applicant's attention is drawn to the Party Wall Act 1996 which sets out requirements for notice to be given to relevant adjoining owners of intended works on a shared wall, on a boundary or if excavations are to be carried out near a neighbouring building.

INFORMATIVE: Hours of Construction Work

The applicant is advised that under the Control of Pollution Act 1974, construction work which will be audible at the site boundary will be restricted to the following hours:-
8.00am - 6.00pm Monday to Friday
8.00am - 1.00pm Saturday
and not at all on Sundays and Bank Holidays.

- 1 You can find advice in regard to your rights of appeal at:
<https://www.gov.uk/appeal-householder-planning-decision>
- 2 This notice relates solely to a planning decision and does not purport to convey any approval or consent which may be required under the Building Regulations or any other statutory purpose.
If you intend to submit an appeal that you would like examined by inquiry then you must notify the Local Planning Authority and Planning Inspectorate (inquiryappeals@planninginspectorate.gov.uk) at least 10 days before submitting the appeal.
- 3 For more information about making a Building Regulations application, please contact Haringey Council Building Control Team by email building.control@haringey.gov.uk, telephone 020 8489 5504, or see our website at www.haringey.gov.uk/buildingcontrol.

